

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2018/SZ/ 1335

Dated: 07/06/18

**FIRE SAFETY CERTIFICATE**

Certified that the Rainbow Kids Valley School, located at RZ-2-D, Plot No.10-G, Block-B, Kailash Puri, Delhi-110045, comprised of small basement ground plus four upper floors & one room at fifth floor ( **small basement & newly constructed 4<sup>th</sup> floor & 1 room at 5<sup>th</sup> floor are closed/sealed & not in use**) have complied with the fire prevention & fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of fire Service on 24.4.2018 in presence of Sh Saurabh Kashyap (Owner) and that the premises / building is fit for occupancy Class B "Educational Building" **for ground plus three upper floors** with effect from 07/06/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 40 printed overleaf.

Issued on .....07/06/18..... at New Delhi by

*VK*  
*7/6*  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
*Jc*  
*Suy*

Copy to:-

- 1 The Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Principal, Rainbow Kids Valley School, located at RZ-2-D, Plot No.10-G, Block-B, Kailash Puri, Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (Ground & three upper floor)		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Directorate of Education Circular . No. F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.3.2011		
6	Date of inspection	24.4.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Saurabh Kashyap (Director)		
9	Year of construction	2005		
10	Applicant's letter No.	Nil Dated 17.02.2017	Building is comprised of Small basement, ground plus 4 upper floor & one room at fifth floor.	

**Small basement & Newly constructed 4th floor & one room at 5th floor are sealed & not in use**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education Circular dated 01.3.2011	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A.	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	<del>One</del> Two	Two	MR
	2. basements	N/A	Not under consideration	Closed/Not in use
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional staircase of .75 Mtr. is required	1.50 & 1.37 Mtrs.	MR
	2. basements	N/A	(not under consideration as closed & not in use)	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors	12 ac charge	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. each floor	9 Nos.	MR
	Types	CO2 OR ABC	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR




	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One	One	
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			N/A
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	Provided	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
15	<b>Exit Signage.</b>	Required	Not provided	NMR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N/116

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: near electric pannel	ABC Fire extinguisher Provided MR		


Fire protection systems provided in the building were checked & found functional at the time of inspection. Keeping In view substantial compliance of minimum standards of fire prevention & fire safety required as per DOE Cir. dated 1.3.2011, grant of Fire Safety Certificate is recommended under rule 35 of the Delhi Fire Service rules 2010 under Act 2007.


Accordingly DFA is put up for approval and signature please.

  
M K Chattopadhyay  
DO (SouthWest)

  
S.P. Bhardwaj  
ADO (Dwarka)

DCFB (SZ)



  
8-5-18  
2475

  
9/5

1377/cfb sz  
11/5/7-6

cfu sz PA speak 11/5  
DCFB SZ

  
16-5-18  
2475

  
16/5  
  
12/5

257/DO (SW)  
dt- 17/05/18

ADO (DWR)