

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/EH/2018/WZ/ 142)

Dated: 18/06/2018

FIRE SAFETY CERTIFICATE

Certified that the **M/s Capital Grill (a unit of JPS Fine Dining LLP)** located at **A – 4, Ground Floor, Vishal Enclave, New Delhi** in a building comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/EH/2015/WZ/561 Dated -21/04/2015. The premises was re inspected by the officers concerned of this department on **02-06-2018** in the presence of **Mr. Anil Suri** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Ground Floor Only) with effect from 18/06/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on18/06/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. M/s Capital Grill (a unit of JPS Fine Dining LLP), A – 4, Ground Floor, Vishal Enclave, New Delhi.
2. Dy. Health Officer, West Zone, SDMC, Public Health Department, Vishal Enclave, New Delhi.
Following fire safety directives must be adhered to:-
 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
 2. **This NOC is valid for Ground Floor only.**
 3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
 4. The trained staff should be available round the clock.
 5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
 6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
 7. Basement shall be used as per building bye laws.
 8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
 9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Capital Grill (a unit of JPS Fine Dining LLP) located at A – 4, Ground Floor, Vishal Enclave, New Delhi.
2. Type of Occupancy : Assembly on ground floor only in a building comprised of Basement + G + 3 Upper Floors.
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2015/WZ/561 Dated -21/04/2015
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 02-06-2018
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Mr. Anil Suri
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dated -06/04/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	On Road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1m	2X204 cm, 1X102cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	04 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NR	Provided	NR
	<ul style="list-style-type: none"> • Location of Main Panel 	NR	Provided	NR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NR	NR	NR
	<ul style="list-style-type: none"> • Alternate source of power 	NR	Provided	NR
	<ul style="list-style-type: none"> • Hooters' Location 	NR	Provided	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NR	NR	NR
	<ul style="list-style-type: none"> • Upper Floor 	NR	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NR	NR	NR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> ● Ground Level ● Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access ➤ Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> ● Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank ● Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	Provided	MR
		10000 litres	10000 litres Provided	MR
		Required	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2015/WZ/561 Dated -21/04/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~

~~Signature of the Inspecting Officer~~

~~Name Uday Mr Singh~~

~~Name~~

~~Designation AD/OWP~~

~~Designation~~

~~Dy. CPD~~ ~~12/6/18~~

~~Dy. CPD WZ - EIC~~

~~CPD WZ~~ ~~13/06/18~~

FT Pls as commlr

~~DO/W~~ ~~14/6/18~~

~~AD/WZ~~

Sir AP

letter is not up for sign plz.

~~CPD~~

~~18/06/18~~

~~18/6/18~~

~~AP~~