

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2018/1437

Dated: 20/06/2018

FIRE SAFETY CERTIFICATE

Certified that M/s. Hotel Royal Palace located at 11A/27, WEA, Channa Market, Karol Bagh, New Delhi- 110005 is comprised of ground plus four upper floors, using ground floor as reception, offices & staff rooms, first floor having 05 guest rooms, second floor having 06 guest rooms, third floor having 03 guest rooms & 03 rooms for personal use, fourth floor having 06 guest rooms (total 20 guest rooms), was granted FSC by this department vide letter No. F.6/DFS/MS/GH/2015/SZ/1088 dated 26.06.2015. The premises was re-inspected by the officer concerned of this department on 11.06.2018 in presence of Sh. Ajay (Manager), and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) with effect from 20/06/2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 20/06/2018 at New Delhi by.

19/6
(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. Sh. Om Prakash Chopra (Director), Hotel Royal Palace, 11A/27, WEA, Channa Market, Karol Bagh, New Delhi- 110005.
2. The Addl. C.P. (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Hotel Royal Palace, 11A/27, WEA, Channa Market, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/GH/2015/SZ/1088 dated 26.06.2015.
5. Fire Safety directives letter No : Nil
6. Date of inspection : 11.08.2018
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO(South West)
8. Name and designation of officers from the building side : Sh. Ajay, manager
9. Year of Construction : 1989
10. Applicant's letter No. : HRP/DEL/2018 dated 16.05.2018

The said guest house is comprised of ground plus four upper floors .

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per letter dt. 26.06.2015	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts	Provided	MR
		4.5 mts	Provided	MR
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Old Case	01	MR being old case
		N/A	N/A	N/A
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Old case	1.28 mts	MR being old case
		N/A	N/A	N/A
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	2.0 mts	MR
	h. Door Size	Old case	0.87 mts	MR being old case
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	Sealed	----
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

		Required	Provided	MR
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Old case	5000 lts	MR, Old case
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/GH/2015/SZ/1088 dated 26.06.2015, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

673/20/150
13/6/2018

DCFO (SZ)

[Handwritten signature]
13/6

[Handwritten signature]
13/6/18

Signature of the Inspecting Officer
Name M.K.CHATTOPADHYAY
Div. Officer (South West)

1. ITR. 11