

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO.F6/DFS/MS/School/2018/SZ/ 1429

Dated: 19.06.2018

FIRE SAFETY CERTIFICATE

Certified that the Mata Kaushlaya Public School located at plot No.22-23, Tara Nagar, Kakrola Road, New Delhi-110043, comprised of ground floor plus one upper floor, having total 12 rooms (Including Class Rooms, Office & Store etc.) was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2013/28 dated 03.01.2013. The said school building was re-inspected by the officer concerned of this department on 28.5.2018 in presence of Sh. Ajay Kumar (Teacher) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17.1.2005 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from...19.06.2018... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on19.06.2018..... at New Delhi by


Vipin Kental
Chief Fire Officer


Copy to:-

1. Director (Education), GNCT of Delhi, old Secretariat, New Delhi-110054.
2. The principle Mata Kaushlaya Public School plot No.22-23, Tara Nagar, Kakrola Road, New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADo/DUK

INSPECTION REPORT

1	Name & address of the building	Mata Kaushlaya Public School, Plot No. 22-23, Tara Nagar, Kakrola Road. New Delhi-110043		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	F6/DFS/MS SCHOOL/2013/28 dated 03.01.2013		
5	Fire safety directives letter No	Directorate of Education Circular No. 262-362 dated 17.1.2005		
6	Date of inspection	28.05.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Ajay Kumar (Teacher)		
9	Year of construction	Before 2006		
10	Applicant's letter No.	Nil Dated 14.05.2018	Ground floor plus one upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 17.1.2005/ letter dated 4.12.2006	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1.5 Mtrs., if less than 1.50 Mtr. Additional staircase of .75 Mtr. is required		1.08 Mtrs. & 1.06 Mtrs.	MR being old case
	1. Upper floors			
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	MR
	e. Width of corridor	1.50 Mtrs.	1.42 Mtrs.	MR being old case
	f. Door size	1 Mtr.	.89 Cms. & 194 Cms.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A

5	Fire Extinguishers			
	total numbers	1 CO2 OR ABC for every 300 Sq. Mtrs. ISI	4 Nos	MR
	Types		CO2 & ABC	MR
	ISI marking		Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	M/R

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any; ABC fire extinguisher provided near electric meter.	M/R		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement as per DOE Cir. Dated 17.1.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2013 dated 3.1.2013 is recommended.

Accordingly DFA is put up for your approval and signature please.

Sury
4/6/18
S.P. Bhardwaj
ADO (Dwarka)

Received on 6/4/18 *DO/SW*

DO/SW
27/6/18

627/2018W
06/06/2018

DO/SW

1518/CF S2
19/6/18

DO/SW



CFO(S2) m/s cell FTD. 8/6

FT is put up for signature

DO/SW / m/s cell 13/6/18

Sury
13/6/18