

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Jan 2018/1472

Dated: 22/6 /2018

FIRE SAFETY CERTIFICATE

4 Certified that the Building at Plot No. C-2, Udyog Nagar, Rohtak Road, New Delhi-110041, comprised of Basement & Ground Floor only owned / occupied by Micro Footwears Pvt. Ltd., has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/2013/WZ/1063 dated 10/10/2013. The premises was re-inspected by the officer concerned of this department on 08.06.2018 in the presence of Sh. Janardan Dubey and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the building / premises is fit for occupancy class **Industrial** with effect fromfor a period of 3 (three) years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on.....at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to:

1. Authorized Signatory, Micro Footwears Pvt. Ltd., Plot No. C-2, Udyog Nagar, Rohtak Road, New Delhi-41.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. Basement shall be used strictly as per BBL.

INSPECTION REPORT

1. Name & address of the building: Micro Footwears Pvt. Ltd., Plot No. C-2, Udyog Nagar, Rohtak Road, New Delhi-41.
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/2013/WZ/1063 dated 10/10/2013
6. Date of inspection : 08/06/2018
7. Name of the Inspecting Officer : A.D.O. (JWP)
8. Name and designation of Officer
from the building side : Mr. Janardan Dubey
9. Year of Construction : 2000
10. Applicant's letter No. : -Nil

Basement + Ground Floor
Plot Area – 3006.69m ²
Covered Area of Basement – 1464m ²
Covered Area of Ground – 1464m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	2	4	MR
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Old Case	1.75 mtr x4	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.20 mtr	1.50 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	15	30	MR
	• Types	ISI marked DCP/CO ₂ /WCO ₂	Provided	MR
	• IS marking	Required	Provided	MR

AB

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30mtr.	30mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power supply	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	NR	Provided	NR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	4	4	MR
	• Hose Box	4	4	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	Not mentioned in guidelines	2280 LPM	MR
	➤ Head of main pump	Not mentioned in guidelines	60 MH	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	Not mentioned in guidelines	900 LPM	MR
	➤ Head of the pump	Not mentioned in guidelines	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	1,00,000 ltr	MR

	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	At DG Set, /Foam Fire Extinguisher required.	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2013/WZ/1063 dated 10/10/2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/w)

[Signature]
19/6/18

[Signature]
12/6/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Dy. CFO (WZ) - EIC

~~CFO (WZ) / 20/06/18~~

AT P/S

F.T. is put up for sign. pl.

[Signature]

CFO (WZ) / 21/6/15

[Signature]
21/6/15