

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2018/WZ/School/1447

Dated: 20/06/2018

FIRE SAFETY CERTIFICATE

Certified that the **Modern Public School**, Located at **BM – Block, Shalimar Bagh Delhi- 110088**, comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2015/WZ/774 Dated- 15-05-2015 The premises was re inspected by the officer concerned of this department on **02-05-2018** in the presence of **Sh. Ashish (Caretaker)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular No- 3298-3398 Dated-01/03/2011 and that the premises is fit for occupancy class “Educational” Group B(**Except Temporary shed at terrace & Ground Floor**) with effect from 20/06/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on20/06/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Principal, Modern Public School, BM – Block, Shalimar Bagh Delhi- 110088.
2. Director of Education, Old Secretariat, Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. **Temporary shed at terrace and Ground Floor shall not be used for any purpose.**
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Modern Public School, Located at BM – Block, Shalimar Bagh Delhi- 110088.**
2. Type of Occupancy : Educational (Ground + 2 Upper Floor) **Except Temporary shed at terrace & Ground Floor)**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/774 Dated- 15-05-2015
5. Fire Safety directives Letter No. : Cr.No- 3298-3398 Dated-01/03/2011
6. Date of inspection : 02- 5-2018
7. Name of the Inspecting Officer : Udaivir singh, ADO (WP)
8. Name and designation of Officer
from the building side :Sh. Ashish (Caretaker)
9. Year of Construction : 1971
10. Applicant's letter No. : MPS/2018/4222 Dated-25/04/2018

No. of Students=2636
No. of class rooms=62
Plot area=2 acres
Covered area=54408sqf

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. 3298-3398 Dated-01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided > 09m Provided 370cm NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	1.5m	210cm Provided	MR
	f. Door Size	1m	100cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	20nos.	25 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	02	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	Provided	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm & 180 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltr	15000 ltr provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
		NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage			
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no: F6/DFS/MS/2015/WZ/774 Dated- 15-05-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer ~~11/6/18~~
 Name Uday Vir Singh
 Designation ADO/WP

Signature of the Inspecting Officer
 Name
 Designation

ADO/WP ~~11/6/18~~
11/6/18
By: CFO (WZ) - EIC
CFO (WZ) 12/06/17 TTPS

ADO/WP Sir AF letter is put up for file

Please
~~12/06/17~~
~~18/06/17~~
M