

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**



NO.F6/DFS/MS/School/2018/SZ/ 1418

Dated: 18/06/18

**FIRE SAFETY CERTIFICATE**

Certified that the Sevti Devi Memorial Sr. Sec. Vidhya Mandir located at Main Palam Dabri road, Mahavir Enclave Opposite Dashrathpuri Metro Station, (Dwarka) New Delhi-110045, comprised of small basement, ground plus one upper floor was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/2009/1455 dated 25.5.2009. The said school building was re-inspected by the officer concerned of this department on 11.6.2018 in presence of Mrs. Parbha Vats (Principle) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17.1.2005 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from....18/06/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on .....18/06/18..... at New Delhi by

  
Vipin Kental  
Chief Fire Officer  


Copy to:-

1. Director (Education) SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
2. Principle, Sevti Devi Memorial Sr. Sec. Vidhya Mandir located at Main Palam Dabri road, Mahavir Enclave Opposite Dashrathpuri Metro Station, (Dwarka) New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

	Name & address of the building	Seviti Devi Memorial Sr. Sec. Vidya Mandir, Main Palam Dabri Road, Mahavir Enclave, opp. Dasrathpur Metro Station (Dwarka) New Delhi-110045		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	F6/DFS/MS/2009/1455 Dated 25.05.2009		
5	Fire safety directives letter No	Director of Education Cir.No.262-362 dated 17.01.2005		
6	Date of inspection	11.06.2018		
7	Name of the inspecting Officers :	S.P. Bhardwaj ADO Dwarka		
8	Name and designation of officers from the building side	Mrs.Parbha Vats (Prinicpal)		
9	Year of construction	Before 2009		
10	Applicant's letter No.	F.1-2/SDMSSVM/F/2009 dated 11.05.2018	<b>Ground plus one upper floor(Small basement)</b>	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>DOE Cir. Dated 17.01.2005/ letter dated 25.5.2009</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	M/MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	2 Nos.	2 Nos.	M/R
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.66 & 1.18 Mtrs.	MR being old case
	2. basements	1.5 Mtrs	1.06 & .54 Cms	MR being old case
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	MR
	<b>e. Width of corridor</b>	1.50 Mtrs.	2.47 Mtrs.	MR
	<b>f. Door size</b>	1 Mtr.	.90 Cms.	MR being old case
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 AC Change 12 AC change	Exhaust fan Provided	M/R
	upper floors		Provided	M/R

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	1 ABC for every 300 Sq. Mtrs.ISI	4 Nos.	MR
	Types		ABC	MR
	ISI marking		Provided	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One each floor	Provided	M/R
	Length of Hose reel hose	30 m	Provided	M/R
	Nozzle Diameter	5 mm	Provided	M/R
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	Provided at ground floor	N/A
	hose Box	N/A	Provided at ground floor	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2.Terrace level</b>			
	a. Discharge of pump	220 LPM	220 LPM	MR
	b. head of the pump	40 M	40 M	MR
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	2500 ltrs.	Provided	M/R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M/R

NIS

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any; ABC Fire extinguisher provided near electric Panel</b>	M/R		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement as per DOE Cir. Dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2009/1455 dated 25.5.2009 is recommended.

Accordingly DFA is put up for your approval and signature please.

*S.P. Bhardwaj*  
11/6/18  
S.P. Bhardwaj  
ADO (Dwarka)

*DOSW*

*12/6/18*

*684/DOSW*  
*11/6/2018*

*DCFO (S2)*

*13/6*



*CFO (m) m.s cell FT/M. 14/6*

*15/5/CA & 15/6*

*FT is put up for signat plan*

*CFO/S2*

*Sey*