

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/


1481

Dated: 21/6/18

FIRE SAFETY CERTIFICATE

Certified that **St. Vincent Pallotti School** located at L-1501/9, Church Colony, Sangam Vihar, New Delhi-110062 comprised of Basement, Ground + 01 upper floor was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/1009 dated 15-06-2015. The premises was re-inspected by officer concerned of this department on 26/05/2018 in the presence of Fr. George Kutty (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17.01.2005 issued by Director of Education, Govt. of NCT of Delhi. and that building is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 21/06/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to: -

1. Manager, St. Vincent Pallotti School at L-1501/9, Church Colony, Sangam Vihar, New Delhi-110062
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

## INSPECTION REPORT

1	Name & Address of the Building	St. Vincent Pallotti School at L-1501/9, Church Colony, Sangam Vihar, New Delhi-110062		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground + 01 upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2015/1009 dated 15-06-2015		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17/01/2005		
7	Date of Inspection	26-05-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Fr. George Kutty (Manager)		
10	Year of construction	2003   School is running at ground and 1 <sup>st</sup> floor		
11	Applicant letter No.	Outdoor Diary No. 6872 dated 02-05-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Required -NA- -NA-	6 mtr 4.5 mtr -NA-	MR -NA- -NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m / 0.75m	1.54m each	MR
	➤ Basement floor	1.5m / 0.75m	1.54m & 1.75m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	Two	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	Exhaust fan provided Natural Ventilation	MR MR
5.	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	Required ABC / CO2 ISI marked	08 Nos W.Co2 & ABC type Provided	MR MR MR
6.	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	Two 30 mtr 5 mm	Provided Provided Provided	MR MR MR

St. Vincent Pallotti School at L-1501/9, Church Colony, Sangam Vihar, New Delhi

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"><li>• Type of detectors</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Location of Main Panel</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Location of Repeater Panel</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Alternate source of power</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Hooter's location</li></ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"><li>• Basement</li></ul>	Required	Provided	MR
	<ul style="list-style-type: none"><li>• Upper floors</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Sprinkler above false ceiling</li></ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"><li>• Size of Riser/Down-comer</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Number of Hydrant per floor</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Hose box.</li></ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"><li>• Total number of hydrants.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Hose box.</li></ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"><li>• <b>Ground Level</b></li></ul>			
	<ul style="list-style-type: none"><li>➤ Discharge of main pump.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Head of main pump.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Number of main pumps.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Jockey Pump output.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Jockey Pump head.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Standby Pump output.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Standby Pump head.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Auto Starting / Manual Stopping.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Pump house access.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• <b>Terrace Level</b></li></ul>			
	<ul style="list-style-type: none"><li>➤ Discharge of pump.</li></ul>	450 LPM	Provided	MR
	<ul style="list-style-type: none"><li>➤ Head of pump.</li></ul>	40 mtr	Provided	MR
	<ul style="list-style-type: none"><li>➤ Power supply.</li></ul>	Required	Provided	MR
	<ul style="list-style-type: none"><li>➤ Auto starting of pump.</li></ul>	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"><li>• Underground tank capacity.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Draw-off connection.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Fire Service Inlet.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>➤ Access to tank.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Overhead tank capacity.</li></ul>	5.000 Ltr	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"><li>• Pressurization of lift shaft.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Pressurization of lift lobby.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Communication in lift car.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Fireman's switch.</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Lift signage.</li></ul>	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"><li>• Total area</li></ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"><li>• Location</li></ul>	-NA-	-NA-	-NA-

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular, the FSC issued vide letter No. F.6/DFS/MS/School/2015/1009 Dated 15-06-2015, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
25/6/18

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)


St. Vincent Pallotti School at L-1501/9, Church Colony, Sangam Vihar, New Delhi

DO (SD)

*D. Kumar*  
14/6/18

*dy. CFO*  
15/6/18

*dy. CFO*  
13/6



CFO S2 m.scell

FTM  
14/6

A. F. T. letter for signature please  
*Mehmood*  
25/6/18

1522/CFO/S2  
21-6-18

CFO S2 m.scell  
21/6