

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/School/2018/1331

Dated: 06 / 06 /2018

FIRE SAFETY CERTIFICATE

Certified that **Govt Boys Sr. Sec. School, Bakhtawar Pur Delhi-110036** comprised of **Ground + One Upper Floor** owned/occupied by **Govt Boys Sr. Sec. School** was issued fire safety certificate vide letter no. **F2/DFS/MS/School/2015/WZ/806 dated 20/05/2015**. The premises was re-inspected by the officer from this department on dated **21/05/2018** in the presence of **Sh. Vinay Shanker (Vice-Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education dated 01/03/2011 and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **06 / 06 /2018** for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 06/06/2018 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Govt Boys Sr. Sec. School, Bakhtawar Pur Delhi-110036
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : Govt Boys Sr. Sec. School, Bakhtawar Pur Delhi-36
2. Type of Occupancy : Educational (G + 1)
3. Type of Case : Renewal
4. Details of previous NOC : F2/DFS/MS/School/2015/WZ/806 dated 20/05/2015
5. Fire Safety directives letter No : Direction of Education Cir-01/03/2011
6. Date of inspection : 21/05/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Vinay Shanker (Vice-Principal)
9. Year of Construction : 2014
10. Applicant's letter No. : BGSSS/B.Pur/2017-18 /12 dated 12/04/2018

S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	Directly Accessible	Directly Accessible	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	M/R
	• Basements	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.37 mtr x2	M/R
	• Basements	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	N.A.	N.A.	N.A.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door Size	1 mtr	Provided double doors of 1mtr	M/R

lu

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N.A.	N.A.
		12 a/c per hour	N.A.	N.A.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06	20	M.R
			ABC	M.R
		ISI marked	Yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N.A.	N.A.
		30 m	N.A.	N.A.
		5 mm	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.

12	Yard Hydrants.			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting / Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the pump	N.A.	N.A.	N.A.
	➤ Power Supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.

18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F2/DFS/MS/School/2015/WZ/806 dated 20/05/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


11/5/18


Signature of the Inspecting Officer

Name : Rajesh Kumar


Designation: Asstt. Divisional Officer

Dyctof/w2



26/5/18

CFO w2

30/5/18

FT Pls

Asstt. Div. Officer


As approved, f.t. letter is being put up for your signature @

CFO/w2

31/05/18

11/5/18

mu