

FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI - 110001


No. F6/DFS/MS/2018/WZ/ BNOT/1413

Dated: 15/06/2018

FIRE SAFETY CERTIFICATE

Certified that **M/s Rain Tree Grand Banquet** located at **A - 7, 8 Ground Floor and First Floor, Kailash Park, Main Nazafgarh Road, Kirti Nagar, (opp. Metro Pillar No. 326), New Delhi - 110015** in a building comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2015/WZ/627 dated 28-04-2015 owned/ occupied by **M/s Rain Tree Grand Banquet**. The premises was re inspected by the officers concerned of this department on 08-06-2018 in the presence of Mr. Arun Sehgal (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 15/06/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15/06/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service.

Copy to:

1. M/s Rain Tree Grand Banquet, A - 7, 8 Ground Floor and First Floor, Kailash Park, Main Nazafgarh Road, Kirti Nagar, (opp. Metro Pillar No. 326), New Delhi - 110015.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, New Delhi.

Following fire safety directives must be adhered to:-

1. **This NOC is valid only for Ground + 1st Floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per Building Bye Laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: M/s Rain Tree Grand Banquet, A – 7, 8
Ground Floor and First Floor, Kailash Park, Main Nazafgarh Road, Kirti Nagar,
(opp. Metro Pillar No. 326), New Delhi – 110015. (For Restaurant)
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2015/WZ/627 Dated 28/04/2015
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 08-6-2018
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Arun Sehgal (Owner)
9. Year of Construction : 2004
10. Applicant's letter No.: Nil Dated Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m NA NA	Provided On Main Road NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2 2	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.5m & 1m NA	2X1.5m 220 cm & 1.5m	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NR NR	NR NR	NR NR
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	2m & 1m on each floor	Provided	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR NR NR NR NR	NR NR NR NR NR	NR NR NR NR NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA 12 a/c per hour	Provided Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	12 nos. ABC & CO ₂	Provided Provided	MR MR

	floor			
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Functional	MR
	• Location of Main Panel	Required	Functional	MR
	• Location of Repeater Panel	Required	Functional	MR
	• Alternate source of power	Required	Functional	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Functional	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	NR	Provided	NR
	• Upper Floor	NR	NP	NR
	• Sprinkler above false ceiling	NR	NP	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	NR
	• Number of hydrants per floor	1	Provided	NR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	NR
	➤ Head of the pump	40 m	Provided	NR
	➤ Power supply	Required	Provided	NR
	➤ Auto starting of pump	Required	Provided	NR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2015/WZ/627 dated 28/04/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

13/06/18
 Signature of the Inspecting Officer
 Name *Udai Vir Singh*
 Designation *ADD/OP*

Signature of the Inspecting Officer
 Name
 Designation

DO/W
13/06/18

Dy. CFO (WZ) - E/L

CFO (WZ) / E/L
13/06/18

put up FT as commd

13/06/18

DO/W

Corrected F.T./FSL is put up for signature please.

CFO (WZ) / E/L
14/06/18

14/6/18