

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/Auditorium/2018/SZ/ 1344

Dated: 08/06/2018

**FIRE SAFETY CERTIFICATE**

Certified that the Auditorium at India International Centre located at 40, Max Muller Marg, New Delhi-110003, comprised of ground floor only was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Auditorium/2015/SZ/242 dated 19/02/2015. The said premises was re-inspected by the officer concerned of this department on 15/05/2015 in presence of Mr. Vikram (Care-taker) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly** (Auditorium) as above with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/06/2018 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to:

1. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. Sh. Amod K. Dalela (Admn. Officer), India International Centre Auditorium, 40, Max Muller Marg, New Delhi-110003

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of
6. UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

## INSPECTION REPORT

1	Name & Address of the Building	Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-110003		
2	Type of Occupancy	Assembly (Auditorium with 231 seats)		
3	Building Comprised of	Ground floors only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Auditorium/2015/SZ/242 Dt. 19-02-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	15-05-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Vikram (Care-taker)		
10	Year of construction	1961		
11	Applicant letter No.	1269-63/Addl. C.P/Lic. (Amst.) dated 18/04/2018		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	6 mtr	8 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	One	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1.5m (two)	1.7m (two) & 0.80m	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Auditorium	12 ACPH	Exhaust fan provided	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	10 Nos	MR
	• Types	ABC / CO2	ABC, CO2 & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	02 Nos	Provided in Audi	MR
	• Length of hose-reel hose.	30 mtr	30 mtr	MR
	• Nozzle Diameter	5 mm	5 mm	MR

Auditorium at India International Centre, 40, Max Muller Marg, New Delhi



7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>	Fire fighting system is common for entire complex		
	➤ Discharge of main pump.	2280 LPM	2280 LPM	MR
	➤ Head of main pump.	75m	75m	MR
	➤ Number of main pumps.	02 Nos	02 Nos	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	75m	75m	MR
	➤ Standby Pump output.	2280 LPM	2280 LPM	MR
	➤ Standby Pump head.	75m	75m	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	35m	35m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	50,000 Ltr	50,000 Ltr	MR
		Required	Required	MR
		Required	Required	MR
		Required	Required	MR
		20,000 Ltr	20,000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	Required	Provided DG Set	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

Auditorium at India International Centre, 40, Max Muller Marg, New Delhi

N/ 3A

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	02 CO2 type fire extinguishers provided in projection room	MR

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/Auditorium/2015/SZ/242 dated 19/02/2015, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

*[Handwritten Signature]*  
28/5/18

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

Auditorium at India International Centre, 40, Max Muller Marg, New Delhi

DO (SD)

*[Handwritten Signature]*  
29/5/18

*[Handwritten Signature]*

*[Handwritten Signature]*  
29/5



1473/CFO/SZ  
7-6

Cfo 371 m.scell FTB. 30/5.  
A.O.T. letter put up for signature please  
*[Handwritten Signature]*  
28/5/18  
CFO/SZ m.scell 7/6.