

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/2018/CNG / 1321

Dated: 05/06/18

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) located at Loni Road, Delhi, comprised of ground floor only, owned/occupied by Indraprastha Gas Limited was issued FSC vide letter no- F6/DFS/MS/CNG/2015/NDZ/512 dated-21/04/2015. The premises was re-inspected by the officer concerned of this department on 10/05/18 in the presence of Manager found that prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules 2010 and the building/premise is fit for occupancy class "Storage (CNG Pump) with effect from ... 05/06/18... for a period of **three** years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on..... 05/06/18 at New Delhi by

Ventat
(Vipin Kental)
Chief Fire Officer
Ph.011-23414333

To,

The Chief General Manager (Fire & Safety),
IGL Bhawan, Plot No-04, Community Center,
R.K. Puram Sector-09, New Delhi-110022

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
9. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.

NIG

1. Name & address of the building : CNG Dispensing Station at Loni Road, Delhi.
2. Building is comprised of : Ground floor
3. Type of Occupancy : CNG Storage & Dispensing Unit
4. Type of Case : Renewal
5. Details of Previous FSC letter no. : F6/DFS/MS/CNG/2015/NDZ/512
dated-21/04/2015
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 10/05/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer
from the building side : Manager
10. Year of Construction : 2003
11. Applicant's letter No : IGL/F&S/2018/15/09/01 Dated-
07/02/18


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Directives	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtr. 4.5 m N/A	15 mtr. 06 m N/A	MR MR N/A
02	Number, Width, Type and Arrangement of Exits			
	<ul style="list-style-type: none"> • Number of Staircases • Width of Staircases 	N/A N/A	N/A N/A	N/A N/A
03	Compartmentation.	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • DCP type 10 Kg. • DCP type 75 Kg. • CO₂ type 4.5 Kg. • IS marking 	08 nos. 01 nos. 04 nos. ISI marked	08 nos. 01 nos. 04 nos. ISI marked	MR MR MR MR
06	First-Aid-Hose Reels.			
	Total numbers on each floor <ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Alternate source of power • Hooter's location 	Gas Required Required Required	Provided Provided Provided Provided	MR MR MR MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A

NIT

13	Pumping Arrangements.			
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage / No Smoking Signage	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection Systems			
	• CO ₂ , DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR


The fire protection systems provided in the CNG station were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The Fire Safety Certificate issued vide this department letter no. F6/DFS/MS/CNG/2015/NDZ/512 dated 21/04/2015 renewal under the rule 37 of the Delhi Fire Service Rules 2010 is recommended.


14/5/2018

Signature of the Inspecting Officer
Name- R.K.Yadav
Designation- ADO (LN)

DO(ED)
S720/CFO/NDZ
30-8


16/5
DYUFO/NDZ
CFO



FT/OT
17/5

M.Scell

17/5