

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2018/SZ/ 1336



Dated:

07/06/18

FIRE SAFETY CERTIFICATE

Certified that the R.M. Convent School RZ-87/88, Gali No.10, West Kailashpuri, New Delhi-110045, comprised of ground plus one upper floor, have complied with the fire prevention & fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of fire service on 24.5.2018 in presence of Sh.Manjeet Solanki (Manager) and that the building is fit for occupancy class B "Educational building" with effect from....07/06/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on07/06/18..... at New Delhi by


Vipin Kental
Chief Fire Officer


Copy to:-

1. Director (Education) GNCT of Delhi old secretariat New Delhi- 110054.
2. Head Mistress, R.M. Convent School RZ-87/88, Gali No.10, West Kailashpuri, New Delhi-110045

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

N/I

INSPECTION REPORT

1	Name & address of the building	R.M. Convent SCHOOL , RZ-87/88,Gali No.10, West Kailashpuri,New Delhi-110045		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (G+1)		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	24.05.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mr Manjeet Solanki (Manager)		
9	Year of construction	1999		
10	Applicant's letter No.	Nil 197/RMCS/18 dated 27.4.2018	Ground plus one upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE CIR. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs., if less then additional staircase of .75 Mtr. Is required	.85Mtrs & .78 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	1.50 Mtrs.	1.85 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A

5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	24.05.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mr Manjeet Solanki (Manager)		
9	Year of construction	1999		
10	Applicant's letter No.	Nill 197/RMCS/18 dated 27.4.2018	Ground plus one upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE CIR. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs., if less than additional staircase of .75 Mtr. Is required	.85Mtrs & .78 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	1.50 Mtrs.	1.85 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	total numbers	1 CO2 OR ABC for every 300 Sq. Mtrs.	4 Nos.	MR
	Types	ISI	ABC	MR
	ISI marking		Provided	MR

N/3

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. Dated 1.3.2011, grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

S.P. Bhardwaj
ADO Dwarka

S.P. Bhardwaj
28/5/18

Dorajw

[Signature]
29/5/18