

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2018 /1381

Dated: 13 / 6 /2018

FIRE SAFETY CERTIFICATE

Certified that Rohini Educational Society, Sr. Secondary School, Plot No. 3, Sector- 24, Phase- III, Rohini, Delhi (The Sovereign School) comprised of Basement + Ground + Four Upper Floors owned/occupied by Rohini Educational Society, has already been issued fire safety certificate vide letter no. F6/DFS/MS/2015/WZ/761 dated 13/05/2015. The premises was re-inspected by the officer from this department on dated 04/06/2018 in the presence of R. N. Jindal (Chairman) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Rule 33 of Delhi Fire Service Rules 2010 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 13 / 6 /2018 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/6/18 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Rohini Educational Society, Sr. Secondary School, Plot No. 3, Sector- 24, Phase- III, Rohini, Delhi(The Sovereign School)
2. The Director of Education, Old Secretariat, Delhi.

INSPECTION REPORT**Basement + Ground + Four Upper Floors**

1. Name & address of the building : Rohini Education Society, Sr. Secondary School, PKT-3, Sector 24, Phase- III, Rohini, (The Sovereign School)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/761 dated 13/05/2015
5. Fire Safety directives letter No : F6/DFS/MS/BP/2007/3193 dated 25/10/2007
6. Date of inspection : 04/06/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. R.N Jindal (Chairman)
9. Year of Construction : 2007
10. Applicant's letter No. : Nil dated 05/05/2018

Plot Area- 16,000 Sq. Yds. Covered Area- 9237 Sq. Yds.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	20 m	Provided	M/R
	• Gate width	6 m	Provided	M/R
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	Provided	M/R
	• Basements	04	Provided	M/R
	b. Width of staircases			
	• Upper Floors	1.5 m	Provided	M/R
	• Basements	1.5 m	Provided	M/R
	c. Protection of exits			
	• Fire check door	Required	Provided	M/R
	• Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	01	02	M/R
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	01 mtr	Provided	M/R
	Conference hall	2x02 mtr	Provided	M/R

4/77

3	Compartmentation.			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Provided	M/R
	• Fire Rating of shaft door	Required	Provided	M/R
	• Water Curtain	N.A	N.A	N.A
	• Fire Dampers	Required	Provided	M/R
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan Provided	M/R
	• Upper floors	12 a/c per hour	Natural ventilation	M/R
5	Fire Extinguishers			
	• Total numbers	40	40	M/R
	• Types		ABC, Co2 & wco2 type	M/R
	• IS marking	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03 at each floor	Provided	M/R
	• Length of hose reel hose	30 m	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.A	N.A	N.A
	• Location of Main Panel	N.A	N.A	N.A
	• Location of Repeater Panel	N.A	N.A	N.A
	• Alternate source of power	N.A	N.A	N.A
	• Hooters' Location	N.A	N.A	N.A
8	MOEFA	Required	Provided	M/R
9	Public Address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	M/R
	• Upper Floor	N.A	N.A	N.A
	• Sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	• Size of riser/down-comer	(4")	Provided	M/R
	• Number of hydrants per floor	03	Provided	M/R
	• Hose Box	03	Provided	M/R

12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	180 LPM	Provided	M/R
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M/R
	➤ Head of the pump	40 m	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	75,000 ltr	Provided	M/R
	➤ Draw-off connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	Required	Provided	M/R
	• Overhead Tank capacity	25,000 ltr	Provided	M/R
15	Exit Signage.			
		Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

2/15

17	Standby power supply	Required	Provided	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel.	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/WZ/761 dated 13/05/2015. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

14/05/16

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

Dy Gd/W2 - on BIL

Chd. (WZ)

*7/06/16
FI DS*

11/06/16

As approved, f.t letter is put up for your signature PI

Chd. (WZ)

14/11/16