

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2015/136

Dated: 12 / 06 / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Sachedeva Public School**, Located at **FP block Maurya Enclave Pitampura Delhi - 110086**. comprised of Two Block =BL-1=(B + G + 2Upper Floor)BL-2=(G+1 Upper Floor) was issued FSC vide Letter No. F6/DFS/MS/SCHOOL/2015/WZ/1994 Dated 10-06-2015. The premises was re inspected by the officer concerned of this department on **23-05-2018** in the presence of Sh. Virender Vats (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 12/6/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on12/6/18..... at New Delhi by.


(Atul Garg)

Chief Fire Service
Delhi Fire Service

Copy to:

1. The Principal, Sachedeva Public School, FP block Maurya Enclave Pitampura Delhi - 110086.
2. Directorate Of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Sachedeva Public School**, Located at **FP block Maurya Enclave Pitampura Delhi -110086.**
2. Type of Occupancy : Educational Two Block =**BL-1**=(B + G + 2Upper Floor)**BL-2**=(G+1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2015/WZ/1994 Dated 10-06-2015
5. Fire Safety directives Letter No. : 262-362 dated 17-01-2005
6. Date of inspection : 23-05-2018
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side :Sh. Virender Vats (Manager)
9. Year of Construction : 1980
10. Applicant,s letter No :SPS/Admn/FSC/FP/585/2018/2275 Dated-23/03/2018

Plot Area - 7996 M ²
Covered Area -7125 M ²
No. or Class Rooms-66
No. of Student- 2997

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 6 mtrs 5mtrs NA 	<ul style="list-style-type: none"> 7mProvided 4.9 m Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 3 3 1.5m 1.5 m NA NA 2 1.5m 1m 	<ul style="list-style-type: none"> Provided Provided 5 BL-1=1x180cm & 2x160cm BL-2=1x140cm,1x160cm,&1x175cm 1x90cm,2x165cm,1x180cm& 1x140cm Provided NA NA Provided >1.5mProvided 1.1m Provided NA NA NA NA NA NA NA 	<ul style="list-style-type: none"> MR MR MR MR MR MR MR MR MR MR MR MR MR MR MR MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> Exhaust Fans NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA

5.	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ABC & CO ₂ ISI marked	25 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	3 on each floor 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 2 at each floor Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 lpm,180 lpm &220 LPM for BL2 40Mtr NR NR	NA NA NA NA NA NA NA NA NA NA BI-1=450& 180lpm BI-2= 220lpm Provided NP NP	NA NA NA NA NA NA NA NA NA MR MR NR NR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	25,000 ltr NA NA NA 15,000Ltr	50,000 ltr NA NA NA Provided	MR NA NA NA MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2015/WZ/1994 Dated 10-06-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ADDO/WP

Designation

DO/pe
29/5/18
Dy CFO (WZ)

29/5/18

cfo work