

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2018/1304

Dated: 5/6/2018

FIRE SAFETY CERTIFICATE

Certified that **Chaudhary, Chhoturam Memorial Public School, Bhagat Singh Park, Siraspur, Delhi 110042** comprised of **Three Blocks, One Block G + One & Two blocks Ground Floor Only** were issued FSC earlier by this department vide letter no. **F-6/DFS/MS/School/WZ/292 dated 02/03/2015**. The premise was inspected by the officer from this department on **24/05/2018** in the presence of **Sh. Jai Bhagwan Rana (Manager)** and all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 5/6/2018 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 5/6/18 at New Delhi by



(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

Copy to:

1. The Principal, Chaudhary, Chhoturam Memorial Public School, Bhagat Singh Park, Siraspur, Delhi 110042
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT**01 Block Ground + One Floor and 02 Block Ground Floor**

1. Name & address of the building : Chaudhary, Chhoturam Memorial Public School, Bhagat Singh Park, Delhi-110082
2. Type of Occupancy : **Educational**
3. Type of Case : Renewal
4. Details of previous NOC : **F-6/DFS/MS/School/WZ/292 dated 02/03/2015**
5. Fire Safety directives letter No : Director of Education dated 01/03/2011
6. Date of inspection : 24/05/2018
7. Name of the Inspecting Officers : A DO (RN)
8. Name and designation of officers
from the building side : Sh. jai Bhagwan Rana (Manager)
9. Year of Construction : 1996 and 2014
10. Applicant's letter No. : Nil dated 05/04/2018

Plot Area- 4840 Sq.yds. Covered Area-1911 Sq.yds

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	06 mtr	M/R
	• Gate width	Directly Accessible	Directly Accessible	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mtr	2.10 and 1.75 mtr	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1 mtr	1 mtr with door frame	M/R

3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	10	10	M/R
	• Types		ABC	M/R
	• IS marking	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor		N/A	N/A
	• Length of hose reel hose	30 m	N/A	N/A
	• Nozzle diameter	5 mm	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/School/WZ/292 dated 02/03/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

RK
29/5/18

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

Dt cfo/w2

[Handwritten signature]
29/5/18

Cfo need by
29/05/18
FT Pls

As approved, A.T. letter is put for your signature pl.

Cfo/w2
[Handwritten signature]

1/29
01/06/18