

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2018/SZ / 1316

Dated: 05/06/18

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidhalaya, Raj Nagar-1, palam Colony New Delhi. (Code:1821027) comprised of ground & ground floor plus one upper floor was issued fire safety certificate vide this department letter no. F6/DFS/MS/School/2014/SZ/1567 dated 12.12.2014. The Said school building was re-inspected by the officer concerned on 22.5.2018 in presence of Smt. Partima (Vice Principal) and found that the premises have deemed complied the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Saftey/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the premises is fit for occupancy class B "Educational building" with effect from.....05/06/18... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on .....05/06/18..... at New Delhi by

*OC*  
*4/6*  
Vipin Kental  
Chief Fire Officer  
*Suef*

Copy to:-

1. The Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54.
2. Principal, Govt. Sarvodaya Kanya Vidhalaya, Raj Nagar-1 Palam Colony, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

Govt. Sarvodaya Kanya Vidyalaya Raj Nagar-1, Palam Colony, New Delhi 110045

1	Name & address of the building	Govt. Sarvodaya Kanya Vidyalaya Raj Nagar-1, Palam Colony, New Delhi 110045	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renwal (Ground & Ground plus one upper floor)	
4	Details of previous NOC	F6/DFS/SMS/School/2014/SZ/1567 Dated 12.12.2014	
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.	
6	Date of inspection	22.05 .2018	
7	Name of the inspecting Officers	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Smt.Pratima (Vice principal)	
9	Year of construction	1,995	
10	Applicant's letter No.	SKV-727 Dated 06.04.2018	Ground & Ground plus one upper floor

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	M/R
	3) Width of internal road	N/A	N/A.	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	3Nos.	3Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs.	1.50 Mtrs	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	1.5 Mtrs.	1.5 Mtrs.	M/R
	f. Door size	1 Mtr.	1 Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	One Co2 OR ABC for every 300 Sq.	12 Nos.	MR
	Types		ABC	MR

6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	M/R
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/9

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC fire extinguisher provided near electric meter.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of fire safety certificate is recommended.

Accordingly DFA is put up for approval and signature please.

*Surya* 22/5/18  
S.P. Bhardwaj  
ADO (Dwarka)

*B/SW*

*[Signature]*  
23/5/18

*DCFO(S2)*

559/2018  
23/5/18



*[Signature]*  
24/5

FTM.  
*[Signature]*  
25/5

1453/CFOS2  
4-6

*CFOS*

m.scell

FT for signature.

*CFOS*

m.scell *[Signature]*  
4/6

*Surya*  
30/5/18