

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/EH/2018/ 1308

Dated: 5/6/2018

FIRE SAFETY CERTIFICATE

Certified that McDonalds Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi comprised of Ground Floor Only was granted NOC by this department vide letter no F-6/DFS/MS/EH/2015/WZ/930 Dated 08/06/2015. The premises was re-inspected by the officer concerned of this department on 21/05/2018 in the presence of Sh. Dharmender Nath Thakur and observed that all the fire prevention and fire safety arrangement as provided in the premises found in good working condition. The premises have therefore, deem complied with the requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly Building occupancy with effect from 5/6/2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of fire safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on..5/6/18...at New Delhi by

(Atul Garg)

Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Dy. Health Officer, Rohini Zone, Health Department MCD, Sector - 5, Rohini, Delhi
2. Mc Donald's Family Restaurant "D-Mall" Shop No 25-27, Twin District Centre, Rohini, Delhi

2/14

**INSPECTION REPORT**

**Restaurant running on ground floor only**

1. Name & address of the building : McDonalds Family Restaurant "D- Mall" Shop no 25-27  
Ground Floor, Twin District Centre, Rohini, Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2015/WZ/930 Dated 08/06/2015
5. Fire Safety directives letter No : NBC
6. Date of inspection : 21 / 05 / 2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Dharmender Nath Thakur
9. Year of Construction : 2010
10. Applicant's letter No. : L.No- nil Dated 09/04/2018.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09	Provided	M/R
	• Gate width		No gate to premise	--
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits (On Ground Floor only)</b>			
	a. Number of staircases			
	• Upper Floors	N/R	02	N/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 mtr	02 mtr & 1.70 mtr	Being old bldg & issued NOC by deptt. Earlier letter at 26.8.10

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Common with mall	M/R
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Common with mall	M/R
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	Required	Common with mall	M/R
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Separate ventilation for LT panel room provided	M/R
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour		Provided
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	04	04	M/R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ISI marked	ABC type	M/R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	One at each floor	Provided	M/R
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	M/R
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke/Heat	Provided in restaurant	M.R
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	GF	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Common with mall	M.R
8	<b>MOEFA</b>	Required	Provided	M.R
9	<b>Public Address System.</b>	Required	Common with mall	M.R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Common with mall	M.R
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	Provided	M/R
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	Common with mall	M/R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	Common with mall	M/R
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	02	Common with mall	M.R
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	Common with mall	M.R

13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	2280LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		2	Common with mall	M.R
		180 LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		2280 LPM	Common with mall	M.R
		70 m	Common with mall	M.R
		Required	Common with mall	M.R
		Required	Common with mall	M.R
		N/A	Pump house common with "D Mall" & all pumps functional at time of inspection	M/R
		N/A		M/R
		N/A		M/R
		N/A		M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	1,50,000 Ltr	Common with mall	M.R
		Required	Common with mall	M.R
		Required	Common with mall	M.R
		Required	Common with mall	M.R
		10,000 ltr	Common with mall	M/R
15	<b>Exit Signage.</b>	Required	Provided	M/R
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	Required	Provided	M.R
		Required	Provided	M.R
		Required	Provided	M.R
		Required	Provided	M.R
		Required	Provided	M.R
17	<b>Standby power supply</b>	Required	Provided	M/R
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

n/17

19	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	M.R
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	Required	Provided	M.R
	• Batter backup	Required	Provided	M.R
	• Building Floor Plans	Required	Provided	M.R
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	No special risk at present	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/EH/2015/WZ/930 Dated 08/06/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*11/23/15*

Signature of the Inspecting Officer

Name: Rajesh Kumar

Designation: Asstt. Divisional Officer

~~Dy. Insp.~~

~~Asstt. Insp.~~

*[Signature]*  
28/05/18

~~Asstt. Insp.~~  
29/05/18  
FT Ph

~~Asstt. Insp.~~

As approved, P.F. letter is put up for your signature P1

~~Asstt. Insp.~~  
21/06/17

11/23/15

*m*