

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/ 2018/1809

Dated: 5/6/2018

FIRE SAFETY CERTIFICATE

Certified that **Shanti Vidya Niketan School, Ishwar Colony, Bawana, Delhi-110039** comprised of **Ground + One Upper Floor** owned/occupied by **Shanti Vidya Niketan School**, was issued fire safety certificate vide letter no. F6/DFS/MS/2015/School/WZ/355 dated 13/03/2015. The premises was re-inspected by the officer from this department on dated **24/05/2018** in the presence of **Sh. Ravi (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education dated 01/03/2011 and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **5/6/2018** for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 5/6/18 at New Delhi by

(Atul Garg)

Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Shanti Vidya Niketan School, Ishwar Colony, Bawana, Delhi-39
2. The Director of Education, Old Secretariat, Delhi

**INSPECTION REPORT**

1. Name & address of the building : Shanti Vidya Niketan School, Iswar Colony, Bawana, Delhi-110039
2. Type of Occupancy : Educational (G + 1)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/School/WZ/355 dated 13/03/2015
5. Fire Safety directives letter No : Direction of Education Cir-01/03/2011
6. Date of inspection : 24/05/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Ravi (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : SVN/2018 /03 dated 09/04/2018

S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	Directly Accessible	Directly Accessible	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	02	M/R
	• Basements	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 mtr x2	M/R(old case)
	• Basements	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	N.A.	N.A.	N.A.
	• Pressurization	N.A.	N.A.	N.A.
		Required	Provided	M/R
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	1 mtr	1mtr	M/R(old case)
	f. Door Size			

3	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N.A.	N.A.	N.A.
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N.A.	N.A.
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	05	05	M.R
	<ul style="list-style-type: none"> <li>• Types</li> </ul>		ABC	M.R
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Yes	M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	M/R
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	N.A.	N.A.	N.A.
8	<b>MOEFA</b>	N.A.	N.A.	N.A.
9	<b>Public Address System.</b>	N.A.	Provided	N.A.
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N.A.	N.A.	N.A.
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	N.A.	N.A.	N.A.

2/24

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting / Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace level			
	➤ Discharge of pump	220 LPM	220 LPM	M.R
	➤ Head of the pump	40 m	40 m	M.R
	➤ Power Supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	25,00 ltr	Provided	M.R
15	<b>Exit Signage.</b>	N.A.	N.A.	N.A.
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
17	<b>Standby power supply</b>	N.A.	N.A.	N.A.

n/15

18	<b>Refuge Area.</b>			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/School/WZ/355 dated 13/03/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

24/3/15

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

 26/3/15

~~Dy C.O. WZ~~  
~~C.O. WZ~~  
24/3/15

HT 15

As approved, f.t. letter is  
being put up for your signature pl  
1/11/15  
01/03/15

~~C.O. WZ~~  
~~24/3/15~~

