

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 1245

Dated: 28/5/18

**FIRE SAFETY CERTIFICATE**

Certified that the Andhra Education Society Middle School located at Sector-2, R.K. Puram, New Delhi-110022, comprised of ground plus one upper floor, owned/occupied by Andhra Education Society (Telugu Linguistic Minority) have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by the officer concerned of Delhi Fire Service on 26.04.2018 in the presence of Sh. Mahavir Singh (HOS) of the school and that the building/premises is fit for occupancy class 'Educational' Group-B (School) as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 28/5/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. Manager, Andhra Education Society Middle School, Sector-2, R.K. Puram, New Delhi-22
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	Andhra Education Society Middle School, Sector-2, R.K. Puram, New Delhi-110022		
2	Type of Occupancy	Educational, "Group-B" (School)		
3	Building Comprised of	Ground + One upper floor		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298-3398 Dt. 01.03.2011		
7	Date of Inspection	26-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Mahavir Singh (HOS)		
10	Year of construction	1979		
11	Applicant letter No.	AEC/RK Puram/2018-19 dated 04-04-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE circular requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Accessible	9 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors.	Two	Provided	MR
	• Basement floor.	N/A	N/A	N/A
	<b>b. Width of Staircase</b>			
	• Upper floors	1.5m / 0.75m	1.90m & 2.0m	MR
	• Basement floor	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	08 Nos	Provided	MR
	• Types	Co2 / ABC	ABC & CO2	MR
	• ISI Marking	ISI Marking	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

Andhra Education Society Middle School, Sector-2, RK Puram, New Delhi-110022

7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	<b>Standby Power Supply</b>	NA	NA	NA
18.	<b>Refuge Area</b>			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	NA	NA	NA

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

*fn*  
27/4/18

Signature of the Inspecting Officer  
Name: R.N. Singh  
Designation: ADO (BCP)

Andhra Education Society Middle School, Sector-2, RK Puram, New Delhi-110022

DO (SD) Kindly mention the Year of Construction of School in the inspection performa.

*Anilash*  
30/4/18

*ADG*  
*RMS*

sim. land for school allotted in 1973 and school started in building as per record at 13-1-1979. *fn*  
30/4

*oo/sb*

*Anilash*  
21/5/18

*dy. CEO (CS)*



1281/CS2  
146

*and*  
9/5

FTM.

M. scell

*W*  
*UTS*  
*Shree*