

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2018/1194


Dated: 23 / 05 / 2018

FIRE SAFETY CERTIFICATE

Certified that **Delhi Institute of Rural Development (D.I.R.D) Holambi, Delhi 110082** comprised of **Ground + Two Upper Floors**, owned/occupied by **Delhi Institute of Rural Development** was issued fire safety certificate by this department vide letter no. **F6/DFS/MS/2015/WZ/763 dated 13/05/2015**. The premise was re-inspected by the officer concerned of this department on **08/05/2018** in the presence of **Sh. Suresh Sharma (Admn. Officer)** and observed that all the fire safety and fire prevention arrangement as provided in the premises is found in good working condition and there is no additional construction. The premises have therefore deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy **Sub Group B-2 of Group B Educational Building** with effect from **23/05/2018** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on.....**23/05/2018**.....at New Delhi.

  
(Atul Garg)  
Chief Fire Officer  
Ph: 011-23414250

Copy to: -

1. Delhi Institute of Rural Development (D.I.R.D) Behind Holambi Delhi 110082

2/11

**INSPECTION REPORT**

**Ground + Two Upper Floors**

1. Name & address of the building : Delhi Institute of Rural Development (D.I.R.D)  
Holambi, Delhi 110082
2. Type of Occupancy : **Educational Building**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/763 dated 13/05/2015
5. Fire Safety directives letter No : nil
6. Date of inspection : 08/05/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Sh. Suresh Sharma (Admn. Officer)
9. Year of Construction : 2002
10. Applicant's letter No. : DIRD/2017-18/HOL/1567 dated 02/04/2018

	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to building</b>			
	• Road width	6 M	6 M	M/R
	• Gate width	5 M	5 M	M/R
	• Width of internal road	6 M	6 M	M/R
<b>2</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	N.A	N.A	N.A
	b. Width of staircases			
	• Upper Floors	1.50 cm	1.51 & 1.44 cm	M/R (Old case)
	• Basements	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	01	01	M/R
	g. Width of Corridor	1.50 mtr	2.07 mtr	M/R
	h. Door Size	1 mtr	110 & 115 mtr	M/R

2



N/12

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N.A N.A	N.A N.A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	One @ 300 m <sup>2</sup>  ISI marked	06 06 ABC TYPE YES	M.R M.R M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02  30 m 5 mm	Provided YES YES	M.R M.R M.R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N.A N.A N.A N.A N.A	N.A N.A N.A N.A N.A	N.A N.A N.A N.A N.A
8	<b>MOEFA</b>	N.A	N.A	N.A
9	<b>Public Address System.</b>	N.A	N.A	N.A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N.A N.A N.A	N.A N.A N.A	N.A N.A N.A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N.A N.A N.A	N.A N.A N.A	N.A N.A N.A

A

N/13

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.A	N.A	N.A
	• Hose Box	N.A	N.A	N.A
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey Pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby Pump out put	N.A	N.A	N.A
	➤ Standby Pump Head	N.A	N.A	N.A
	➤ Auto Starting/ Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R
	➤ Head of the pump	30	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N.A	N.A	N.A
	➤ Draw-off connection	N.A	N.A	N.A
	➤ Fire service inlet	N.A	N.A	N.A
	➤ Access to tank	N.A	N.A	N.A
	• Overhead Tank capacity	10,000 LTR	10,000 ltr	M.R
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A

k



2/11/15

17	Standby power supply	N.A	N.A	N.A
18	<b>Refuge Area.</b>			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/WZ/763 dated 13/05/2015. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

14/11/15

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

16/5/15

18/5/15  
FIPY

As approved, F.I. letter is being  
your signature etc. 14/23/15

27/05/15