

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/BNQT/2018/WZ/ 1261

Dated: 30 /05/2018

FIRE SAFETY CERTIFICATE

Certified that the **Gola Ceremonials Banquet Hall**, Located at, **8/ 39, Kirti Nagar, Industrial Area, New Delhi – 110015**. was issued FSC vide Letter No. F6/DFS/MS/BNQT/2015/WZ/443 Dated-27/03/15 in a building comprised of (2 Basements + Ground + 2 Upper Floors). The premises was re inspected by the officers concerned of this department on 10-05-2018 in the presence of Sh. Naresh Kapoor (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (**At Ground + 2 Upper Floors**) with effect from 30/5/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on30.5.18.... at New Delhi by.



(Atul Garg)
Chief Fire Service
Delhi Fire Service.

Copy to:

1. The Gola Ceremonials Banquet Hall, 8/ 39, Kirti Nagar, Industrial Area, New Delhi – 110015.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any
6. Basement shall be used as per BBL 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Gola Ceremonials Banquet Hall, 8/ 39, Kirti Nagar, Industrial Area, New Delhi – 110015.
2. Type of Occupancy : Assembly at **Ground + 2 Upper Floors** in a building comprised of 2 Basements + Ground + 2 Upper Floors.
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/BNQT/2015/WZ/443 Dated-27/03/15
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 10-05-2018
7. Name of the Inspecting Officer : Udai vir Singh ADO (WP) *U. D. Singh*
8. Name and designation of Officer
from the building side : Sh. Naresh Kapoor (Owner)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dated 18-04-2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	4	Provided	MR
	b. Width of staircases			
	• Upper floors	2X2m, 1X1.5m	2X2m, 150 cm (Include Railing)	MR
	• Basements	2X2m, 2X1.5m	2X2m, 2X153cm (Include Railing)	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NR	NP	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m, 1X1.5m	GF (1 exits) – 3X2m, 1X121cm, 1X196cm, 1X170cm, 1X190 cm FF (5 exits) – 2X225cm, 1X200cm, 2X162cm, SF (5 Exits) - 2X225cm, 1X200cm, 2X162cm,	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required	Provided	MR
		Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	26 nos.	Provided	MR
		ABC & CO2	Provided	MR
		ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	Provided	MR
		2	Provided	MR
		2	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NR	NR	NR
		NR	NR	NR

Pumping Arrangements			
<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 lpm	Provided	MR
	70 m	Provided	MR
	1	Provided	MR
	180 lpm	Provided	MR
	70 m	Provided	MR
	2280 lpm	Provided	MR
	70 m	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	900 lpm	Provided	MR
	40 m	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14. Captive water Storage for fire fighting			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 litres	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	10, 000 litres	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts (Lift shall run from Ground to upper Floors)			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
	NA	NA	NA
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no F6/DFS/MS/BNQT/2015/WZ/443 Dated-27/03/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
15/5/18

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name
Designation

20/5/18

[Signature]
17/5/18

[Signature]

[Signature]
21/5/18

CFO West

[Signature]
22/05/18

Pls sb
[Signature] on 20/05/18

Do/w

FT PG

10/5/18 Sir FY letter is put up for
Sign ple.

[Signature]
29/5/18

CFO
[Signature]
29/05/18