

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001



No.F6/DFS/MS/School/2018/NDZI/1290

Dated: 04/06/18

FIRE SAFETY CERTIFICATE

Certified that the Inder Public School, 150, Village Mandawali Fazalpur, Delhi-92, running at ground plus one upper floor of the building comprised of ground plus two upper floors owned/occupied by Inder Public School was issued NOC vide letter No. F6/MS/DFS/2008/1813 dated 30/06/08. The school building was inspected by the officer concerned of this department on 08/05/18 in the presence of Mr. Rajender Kumar (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground +1floor only with effect from 04/06/18..... for a period of **three** years, subject to conditions, printed overleaf.

Issued on..... 04/06/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


To,

The Manager,
Inder Public School,
150, Village Mandawali Fazalpur, Delhi-92.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

NR

1. Name & address of the building : Inder Public School at 150, Village Mandawali Fazalpur, Delhi-92.
2. Building is comprised of : Ground plus two upper floor (school at G+1 floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/MS/DFS/2008/1813 dated 30/06/08
6. Fire Safety Circular No. : Circular No.262-362 Dated 17/01/2005
7. Date of Inspection : 08/05/18
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of
Officer from the building side : Mr. Rajender Kumar (Manager)
10. Year of Construction : 2000
11. Applicant's letter No : Dated 04/04/18

N O.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 Mtrs.	One hose length	MR old accepted
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.50 M & .90 M	MR*
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
		N/A	1 No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 M	1.0 M	MR
	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	04 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

Earlier NOC was issued distance of one hose length date 30/06/08.

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5MM	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	220 LPM	Provided	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
4	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	MR
	• Signage.	N/A	N/A	N/A

abu
 24

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F6/MS/DFS/2008/1813 dated 30/06/08 renewal under the circular no.262-362 dated 17/01/2005 is recommended.

R. K. Yadav
24/9/2018

Signature of the Inspecting Officer

Name: R. K. Yadav

Designation: ADO(LN)

DO(ED) *[Signature]*
19/5/18
DY CPO/NDM

[Signature]
- FT/10.

561/CPO/ND3
29/5

CF-CJ m.scell *W 23/5*

Sir, FT letter is put up for signature job

R. K. Yadav
24/9/2018

CPO(ND3) m.scell *W 28/5*