

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No.F.6/DFS/MS/School//NDZ/2018/ 1297

Dated: 04/06/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Jeewan Jyoti Public School, Shaheed Bhagat Colony, Pusta Road, Karawal Nagar, Delhi – 94, comprised of Ground plus two upper floors owned / occupied by Jeewan Jyoti Public School was issued FSC vide letter No. F6/DFS/MS/School2015/NDZ/264 dated 26.02.15. The school building was re-inspected by the officer concerned of this department on 18/05/18 in presence of Sh. Rakesh Kumar, owner of the school and the school building is now comprised of ground plus three upper floors but school is running only on ground plus two upper floors. The School building is fit for occupancy class 'B 'Educational Building' for Ground plus two upper floors only with effect from ..04/06/18.. for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....04/06/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service



To,  
The Principal,  
M/s Jeewan Jyoti Public School,  
Shaheed Bhagat Colony, Pusta Road, Karawal Nagar,  
Delhi- 94.

Copy to:-  
The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi -110053.

**- Conditions -**

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The Third floor shall not be used for school purposes.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"



1. Name & address of the building : Jeewan Jyoti Public School, Shaheed Bhagat Singh Colony, Pusta Road, Karawal Nagar, Delhi -110094.
2. Building is comprised of : G + 3 (Addition Alteration) **running at (G+II) only**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F6/DFS/MS/School2015/NDZ/264 dated 26.02.15.
6. Fire Safety Directive N : NBC Part IV
7. Date of Inspection : 18/05/18
8. Name of the Inspecting officers : DO Francis Brown
9. Name and designation of Officer from the building side : Rakesh Kumar (owner)
10. Year of Construction : 2005
11. Applicant's letter No : Nil Dated: 18/04/2018.

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs	<b>MR</b>
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 no.	02 no.	<b>MR</b>
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.30 & 1.20 m	<b>MR</b>
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	g. Width of Corridor	1.5 m	2.0 m	<b>MR</b>
	h. Door Size	1.0 m	1.0 m	<b>MR</b>
3	Compartmentation.			
	• Fire check door	Required	Provided	<b>MR</b>
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	12 nos.	13 nos.	<b>MR</b>
	• types	ABC & Co2	ABC & Co2	<b>MR</b>
	• ISI marking	ISI marked	ISI marked	<b>MR</b>



NIF

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Siren Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Liters	10,000Liters	MR
15	Exit Signage.	Required	Provided	MR

N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules. It is recommended to issue Fire Safety Certificate.

*Francis Brown*  
23/5/18

Signature of the Inspecting Officer  
Name: Francis Brown  
Designation: DO(East)

DCFO/NDZ

*[Signature]*

The third floor shall not be used for school purposes. Condition added.

FT 17

C.F. - M. scell

*[Signature]*  
25/5

5286/CPD/NDZ  
4-6

FT. bell is prepared and put up for records file.

C. F. H. G.

M. scell

*[Signature]*  
31/5

*[Signature]*  
28/5