

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2018/SZ/ 1292

Dated: 04.06.18

FIRE SAFETY CERTIFICATE

Certified that the Parkash Public School Sector-7, Pocket-II, New Delhi-110045, comprised of Ground plus three upper floors was issued fire safety certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/130 dated 28.01.2015. The said premises was re-inspected by the officer concerned of this department on 3.5.2018 in presence of Sh. Rakesh Vats (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service 2010, and that the building is fit for occupancy class B "Educational building" with effect from...04.06.18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on04.06.18..... at New Delhi by

87c
Vipin Kental
Chief Fire Officer
Jey

Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54.
2. Principal, Parkash Public School, Sector-7, Pocket-II New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADO/Dwarka

INSPECTION REPORT

1	Name & address of the building	Parkash Public School, Sector-7, Pocket-2, Dwarka, New Delhi-110045.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal (Ground plus three)
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/130 dated 28.1.2015
5	Fire safety directives letter No	NBC/ Directorate of Education: F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011
6	Date of inspection	3.5.2018
7	Name of the inspecting Officers	ADO S.P. Bhardwaj
8	Name and designation of officers from the building side	Sh. Rakesh Vats (Manager)
9	Year of construction	2007, 2014
10	Applicant's letter No.	Nil dated 6.4.2018

**Ground plus three
upper floor**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/DOE Cir. 1.3.2011/ letter dated 28.1.2015	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	e. Width of corridor	1.86 to 2.36 Mtrs.	1.86 to 2.36 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	N/A	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	2 Nos. each floor CO2 OR ABC ICL Marked	9 Nos.	MR
	Types		Provided	MR

M/12

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: for electric panel & electric Meter.	Provided ABC Fire Extinguisher MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE circular dated 01.3.2011, renewal of FSC issued vide letter no.F6/MS/DFS/School/2015/SZ/130 dated 28.1.2015 is recommended.

Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
8/5/18
S.P. Bhardwaj
ADO (Dwarka)

D.O.B.W.

[Signature]
8/5/18

487/DOBW
8/5/18

DCFO(S2)

[Signature]
9/5

CFO SF

Pl check previous inspection report for width of corridor & correct it,

DCFO S2

[Signature]
11/5



1370/CF S2
11/5-285



[Signature]
16/5