

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2018/ 1295

Dated: 04/06/18

FIRE SAFETY CERTIFICATE

Certified that the **Puffins International School** located at **364-365, Kotla Vihar, Phase-4, Tilang Pur Kotla, New Delhi-110043** comprised of **Ground Floor only** owned / occupied by **Puffins Society** have complied with the Director of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 21/05/2018 in presence of Sh. Anjit Kumar and that the building / premises is fit for occupancy class **Educational (Group-B)** with effect from 04/06/2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 04/06/18 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Authorized Signatory, Puffins Society, Plot No.-1/2, Kotla Vihar, Phase-4, Tilang Pur Kotla, New Delhi-110043.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Puffins International School, 364,365, Kotla Vihar, Phase-4, Tilang Pur Kotla, New Delhi-110043.**
2. Type of Occupancy : Educational
3. Type of Case : New (**Ground Floor only**)
4. Details of previous NOC : Nil (**Class Room-4, Students-69**)
5. Fire Safety directives Letter No. : DOE Circular Dated 01/03/2011
6. Date of inspection : 21/05/2018
7. Name of the Inspecting Officer : A. K.-Jaiswal (ADO JWP)
8. Name and designation of Officer
from the building side : Sh. Anjit Kumar
9. Year of Construction : 2014
10. Applicant's letter No. : - Nil

Total Area-500 Yards²

Covered Area-350 Yards²

| S No | Minimum standards on fire prevention and fire safety U/R 33 | DOE. Circ. Dated 01/03/2011 Requirements | Provided at site | Remarks MR/NMR |
|------|---|--|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 6 mtr | 6 mtr | MR |
| | • Gate width | 4.5 mtr | 4.5 mtr | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper floors | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | N/A | N/A | N/A |
| | e. Width Of Corridor | N/A | N/A | N/A |
| | f. Door Size | 1.00 mtr | 1.00 mtr | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | | | |
| 4. | Smoke managements System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 2 | 5 | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | M/R |
| | • IS marking | Required | Provided | M/R |

(Handwritten Signature)

| | | | | |
|-----|--|-----|-----|-----|
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | N/A | | |
| | • Discharge of main pump | N/A | N/A | |
| | ➤ Head of main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw of connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Ground Tank | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|-----|-----|
| 15. | Exit Signage | N/A | N/A | N/A |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | N/A | N/A | N/A |
| | ➤ Flow Switch Panel | N/A | N/A | N/A |
| | ➤ PA System Panel | N/A | N/A | N/A |
| | ➤ Batter backup | N/A | N/A | N/A |
| | ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |


Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

D.O./ (w)
 Dy. PO (2/2)
 CFO West
 29/05/18
 24/5/18
 24/5/18
 f i ps
 but up for sign-ple


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : A.D.O. (Jwala Puri)