

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2018/SZ/1259

Dated: 28/5/18

FIRE SAFETY CERTIFICATE

Certified that the SDMC CO-ED Primary School, Sector-3, Phase-1, New Delhi. (Code:1757214) comprised of ground plus one upper floor owned/ occupied by Delhi Government have complied with the fire prevention & fire safety requirements in accordance with DOE Circular no. 3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire service on 18.5.2018 in presence of Smt. Usha Parsad (Principle) and that the premises is fit for occupancy class B "Educational building" with effect from..28.5.18..... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on .....28/5/18..... at New Delhi by

28/5

Vipin Kental

Chief Fire Officer

Copy to:-

1. The Director, (Education), SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
2. Principal, SDMC CO-ED Primary School, Sector-3, Phase-1, New Delhi.

218/11/1

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	S.D.M.C. CO-Ed. Primary School (ID 5717214) Sector-3, Phase-1, Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	N/A		
5	Fire safety directives letter No	DOE Circular dated 1.3.2011		
6	Date of inspection	18.05.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Usha Prasad (Principle)		
9	Year of construction	1984		
10	Applicant's letter No.	Nil Dated 18.5.2018	Comprised of Ground plus one upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/DOE Cir. Dated 1.3.2011	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 mtrs	Provided	MR
	2) Gate width	4.5 mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs. If less than 1.50 Mtrs. Additional staircase of .75 Mtr. Is required	1.05 Mtrs. & 1.03 Mtr.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	one	one	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors		Natural Vent.	MR

4/1/04

5	<b>Fire Extinguishers</b>			
	total numbers	4 Nos. ABC/CO2 type ISI	4 Nos	MR
	Types		ABC	MR
ISI marking	Provided		MR	
6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>		N/A	N/A
9	<b>Public Address System.</b>		N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>		Required	Provided
				MR



415

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	MR
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b> ABC fire exting. Provided near electric meter. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Circular dated 1.3.2011, grant Fire Safety Certificate is recommended.

Accordingly DFA is put up for your approval and signature please.

*S.P. Bhardwaj*  
24/5/18  
S.P. Bhardwaj  
ADO Dwarka

*D.O.S.W*

*24/5/2018*

620/DO/SLO  
24/5/18

*DCFO (S2)*

*29/5*



*Chro sy*

*M. SCELL*

*F7/07*  
*29/5*

918/11/1