

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2018/WZ/1255

Dated: 28/5/18

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation** located at **Subhash Nagar Metro Station (Except PD area)** comprised of Ground, Concourse and Platform was issued FSC vide letter no. F6/DFS/MS/WZ/2014/132 Dated-30/01/2014. The premises was re inspected by the officer concerned of this department on 14-05-2018 in the presence of Kumar Waibav (AM/FIR) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D – 7 with effect from 28.5.18... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28.5.18..... at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Rajesh Agrawal, DGM/ E&M,
DMRC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi – 110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Subhash Nagar Metro Station (Except PD area)
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Ground + Concourse + Platform)
4. Details of previous NOC : F6/DFS/MS/WZ/2014/132 Dated-30/01/2014
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/2745 dated 11-11-2004
6. Date of inspection : 14/05/2018
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Kumar Waibav (AM/FIR)
9. Year of Construction : 2005
10. Applicant's letter No. : DMCR/O7M/Fire/NOC/L-3/2018/03 Dated-16/03/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	On main road	Provided	MR
	• Gate width	5m	On main road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 on each platform	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1x445cm, 1x450cm For each platform	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5m	197cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	35	28 CO2, 7 WCO2	MR
	<ul style="list-style-type: none"> • Types 	CO2 &	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	WCO2 Required	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 			
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150mm	Provided	MR
		2	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	2	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR

13.	Pumping Arrangements			
	Ground Level	All the pumps are connected with generator also		
	• Discharge of main pump	1800lpm	Provided	MR
	➤ Head of main pump	60m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180lpm	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1800lpm	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50000ltrs	Provided	MR
		Required	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity			
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 flooding for ASS, HT, LT panel	Provided	MR
-----	--	------------------------------------	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2014/132 Dated-30/01/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~

Signature of the Inspecting Officer

Name Udayvir Singh

Name

Designation ADO/WP

Designation

~~Dy. WZ~~
~~Dy. WZ~~
~~CFO WZ~~
 12/5/18
 21/5/18
 FPS

21/5/18

~~AO~~
 Sir AT letter is put up
 for sign ple. plz
 23/5/18