

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2018/ w2/1240

Dated 28/5/2018

FIRE SAFETY CERTIFICATE

Certified that the **Flora Convent School** Located at **C- Block, Maharana Pratap Enclave, Pitampura, Delhi-110034**. comprised of Ground + 01 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2009/2067 Dated -09/07/2009. The premises was re inspected by the officer concerned of this department on 07/05/2018 in the presence of Mr. Sunil Dutt and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore been deemed to comply with the fire prevention and fire safety requirements in accordance with Circular No - 262-362 dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 28/5/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on28/5/18..... at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Manager, Flora Convent School, C- Block, Maharana Pratap Enclave, Pitampura, Delhi-110034.
2. Directorate Of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Flora Convent School** Located at, **C- Block, Maharana Pratap Enclave, Pitampura, Delhi-110034.**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/2067 Dated -09/07/2009
5. Fire Safety directives Letter No. : Circular No – 262-362 dated 17-01-2005
6. Date of inspection : 07-05-2018
7. Name of the Inspecting Officer : Uday vir singh, ADO (WP)
8. Name and designation of Officer
from the building side : Mr. Sunil Dutt
9. Year of Construction : 2006
10. Applicant's letter No. : Nil dated -04/04/2018

No. of Students=180
 No. of class rooms=12
 Plot area=803.74 m²
 Covered area=267 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. 262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible Accessible NA	Provided 4 m Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1x150cm	1x121 cm & 1x116cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	172cm	MR
	f. Door Size	1x100cm	107cm	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	05nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location			
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2009/2067 Dated -09/07/2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Kir Singh

Name

Designation

ADD/wp

Designation

~~DO/w~~

~~14/5/18~~

~~Dy. Insp.~~

~~CFO West~~

~~18/5/17~~

~~FT PL~~

~~ADD/wp~~

Sir FY letter is put up for safe plc.

~~CFO~~
~~28/5/17~~

~~m~~

~~16/28/15~~