

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS GH/2018/SZ/ 1276

Dated: 31/5/18

**FIRE SAFETY CERTIFICATE**

Certified that Guest House in the name and style of M/s The GRD Suites situated at Plot No AB-250/1, Khasra No-423, Gali No.-6A, Mahipalpur Extn., New Delhi-110037, comprised of Basement (Parking) Ground floor (Rec., office & 02 G/Rooms), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (07 G/Rooms each), 4<sup>th</sup> floor (personal use), the guest house running at ground, 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> floor only (total 23 guest rooms) was inspected by officer concern of this department on 14/04/2018 in presence of Mr. Mahavir Singh (Proprietor) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class 'Residential' Group-A (Guest House) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/5/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The DHO, South MCD, Public Health Deptt, Najafgarh Zone, New Delhi-110043
2. Auth. Signatory, M/s The GRD Suites at Plot No. AB-250/1, Khasra No-423, Gali No-6A, Mahipalpur Extn., New Delhi-110037

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



INSPECTION REPORT				
1	Name & Address of the Building	M/s The GRD Suites at Plot No. AB-250/1, Khasra No-423, Gali No-6A, Mahipalpur Extn, N. Delhi-37		
2	Type of Occupancy	Residential, 'Group-A' (Guest House)		
3	Building Comprised of	Basement, Ground plus four upper floors.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Mahavir Singh (Proprietor)		
10	Year of construction	1999	Basement (Parking), Gd floor (Rec. + offices + 02 G/rooms), 1 <sup>st</sup> floor to 3 <sup>rd</sup> floor (07 G/rooms each), 4 <sup>th</sup> floor (personal use), <b>Total- 23 Guest Rooms</b>	
11	Applicant letter No.	DHO/NZ/2018/2231 dated 23-03-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 mtr	Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	• Upper floors	One	Provided	MR
	• Basement floor	Two	02 ramps	MR
	<b>b) Width of Staircase</b>			
	• Upper floors	1.25m	1.5m	MR
	• Basement floor	1.25m	3.80m & 3.20m ramp	MR
	<b>c) Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	Two	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	1.9m (final exit)	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	12 Nos	Provided	MR
	• Types	ABC / Co2	ABC type	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

The GRD Suites at Plot No AB-250/1, Khasra No-423, Gali No-6A, Mahipalpur Extn, New Delhi



7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 Ltr.	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-


The GRD Suites at Plot No AB-250/1, Khasra No-423, Gali No-6A, Mahipalpur Extn, New Delhi

19.	<b>Fire Control Room.</b>	• Detector System Panel.	-NA-	-NA-	-NA-
		• Flow Switch Panel.	-NA-	-NA-	-NA-
		• PA system Panel.	-NA-	-NA-	-NA-
		• Battery backup	-NA-	-NA-	-NA-
		• Building floor plan	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-	



Basement is common in Plot No-AB-250/1 & A-250. Ground floor to 3<sup>rd</sup> floors is used for guest house in each building and 4<sup>th</sup> floor of the building is used for personal use as seen during inspection.




The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.


  
 Signature of the Inspecting Officer  
 Name : R.N. Singh  
 Designation: ADO (BCP)

The GRD Suites at Plot No AB-250/1, Khasra No-423, Gali No-6A, Mahipalpur Extn, New Delhi

DO (SD)   
  
 23/4/18

 Sir. As per note 2, tall 22 ramp shall be protected with automatic sprinkler system and shall be counted one of two means of escape and ramp form fully sprinklered systems by   
 Spoken with ADO BCP   
27/4

1368/CF&S  
 11/5

  
 30/4/18

