

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/CNG/2018/SZ/ 1223

Dated: 24/5/18

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at Sector-05, Dwarka, New Delhi-110075, comprised of ground floor only was issued fire safety certificate by this department vide letter no. F6/DFS/MS/CNG/2018/SZ/1255 dated 15.07.2015. The premises was re-inspected by the officer concerned of this department on 04.05.2018 in presence of Sh. Pushpendra Sharma (Addl. Manager- Fire & Safety) and found that the premises have deemed complied with fire prevention & fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy of CNG Filling Station with effect from ...24/5/18... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ...24/5/18... at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:-

1. Sh. Alok Sharma, Chief General Manager Fire & Safety IGL Bhawan, Plot No.4, Community Centre, R K Puram, Sector-9, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s CNG Station (IGL) Sector-5, Dwarka, New Delhi.		
2	Type of Occupancy	Group J: Hazardous (CNG Filling Station)		
3	Type of case	Renewal (Ground floor only)		
4	Details of previous NOC	F6/DFS/MS/CNG/2015/SZ/1255 dated 15.07.2015		
5	Fire safety directives letter No	OISD-179 / F6/DFS/MS/CNG/2013/2594 dated 27.11.2013		
6	Date of inspection	04.05.2018		
7	Name of the inspecting Officers	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Pushpendra Sharma, Addl. Manager (Fire & Safety), Sh. Arun Kumar Mishra (Station Manager)		
9	Year of construction	2014		
10	Applicant's letter No.	IGL/F&S/2018/15/95 dated 2.04.2018	Ground Floor Only	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ OISD-179/ Letter dated 15.07.2015	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9 Mtr	30 Mtrs.	MR
	2) Gate width	4.5 mtr	Direct accssible from Road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	1 No. Up to Roof level	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	1 Mtr.	N/A
	2. basements	N/A	N/A	MR
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	One	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		Natural Ventilation	N/A
5	Fire Extinguishers			
	total numbers	18 Nos.	22 Nos.	MR
	As per IS 2190 & Clause 19 Of OISD 179	CO2,DCP & Water cum mist foam trolley	CO2 4.5 Kg. (5 Nos.) DCP Trolley of 75 Kgs.(2 Nos.) DCP10 Kgs.(15 Nos.) & One Water mist Cum Foam Trolley.	MR
		Required	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	Gas & Flame	Provided in Compressure Package	MR
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required No smoking Boards	Provided.	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/11

17	Standby power supply	Required	Provided GG Set (25 KVA)	MR
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Auto actuated CO2 flooding system for CNG compressor protection found provided and One Water mist cum foam Trolley provided	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirement as per OISD-179, Renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/CNG/2015/SZ/1255 dated 15.7.2015 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
 14/5/18
 S.P Bhardwaj
 ADO (DWARKA)


D/Sw
 455/DCP/ew
 dt. 15/05/18

[Signature]
 15/5/18

DCFO (S2)

~~1403/CP/82~~
17/5

[Signature]
 16/5



CFO S/P m.scell FT 10/11
 UTTIS

FT for Stomachum plan.

[Signature]

m.scell
 23/5

S.P. Bhardwaj
 18/5/18