

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2018/ 1237

Dated: 25/5/18

FIRE SAFETY CERTIFICATE

Certified that the Govt Girls Sr. Sec. School at Mayur Vihar Ph-III, Delhi-96, owned/occupied by Govt Girls Sr. Sec. School, comprised of ground floor was granted FSC vide letter no. No. F.6/DFS/MS/School/2015/NDZ/1215 dated- 10/07/15. The school building was re-inspected by the officer concerned of this department on 16/05/18 in the presence of Mrs. Sandhya Singh (H.O.S) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/cc/Fire Safety/2011/3298 to 3398 dated 01/03/11 and found that the building is fit for occupancy class B "Educational Building" with effect from ... 25/5/18 for a period of **three years**, subject to conditions printed overleaf.

Issued on ... 25/5/18 at New Delhi by


(Vipin Kental)

Chief Fire Officer

To,

The Principal,
Govt Girls Sr. Sec. School,
Mayur Vihar Ph-III, Delhi-96.

Copy to:-

1. The Dy. Director of Education
D-Block, Anand Vihar, Delhi-92.

2. The Principal,
Govt Boys Sr. Sec. School,
Mayur Vihar Ph-III, Delhi-96.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- 117
1. Name & address of the building : GGSS School at Mayur Vihar Ph-III, Delhi-96.
 2. Building is comprised of : Ground floor only
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous FSC letter : F.6/DFS/MS/School/2015/NDZ/1215 dt- 10/07/15
 6. Fire Safety direction letter No : F.16/Estate/cc/Fire Safety/2011/3298 to
3398 dated 01/03/11
 7. Date of Inspection : 16/05/18
 8. Name of the Inspecting officers : ADO R.K.Yadav
 9. Name and designation of Officer
from the building side : Mrs. Sandhya Singh (H.O.S)
 10. Year of Construction : 2002
 11. Applicant's letter no. : GGSS/MV/PH-III/67 dated-03/05/18

S. N O.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m	10 m	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		N/A	N/A	N/A
	f. Door Size			
		1.5 m	1.5 m	MR
		1.0 M	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	05 nos.	14 nos.	MR
		ABC /CO ₂	ABC /CO ₂	MR
	<ul style="list-style-type: none"> • ISI marking 	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2015/NDZ/1215 dated- 10/07/15 it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
14/8/2018

Signature of the Inspecting officer
Name : R.K. Yadav
Designation : ADO (LN)

DO(ED) *[Signature]*
17/5/18
DYUBO/NDZ

[Signature]

CFP
M.Scill
FTM
14/8/18

So, FT letter is put up for signature pl

M.Scill *[Signature]*

R.K. Co
22/8/2018