

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001.

No.F6/DFS/MS/Mercantile/2018/SZ/ 1222

Dated: 24/5/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Reliance Ambit Trade Pvt. Ltd., Commercial Plot No. 1, City Centre, Sector-13, Dwarka, New Delhi, comprised of three basements, ground plus three upper floors was issued fire safety certificate by this department vide letter no. DFS/MS/Mercantile/2014/SZ/1509 dated 3.12.2014. The said building was re-inspected by the officers concerned of this department on 14.5.2018 in presence of Sh. Sunil Kumar Sharma (EGM) & Sh. Vijay Kumar (Mall Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy "Mercantile building" with effect from ...24/5/18..... for a period of **Three** years subject to compliance of the conditions printed overleaf.

Issued on ...24/5/18..... at New Delhi by

OC
(Vipin Kental)
Chief Fire Officer
Sw

Copy to:-

1. Sh. Sunil Sharma, M/S Reliance Ambit Trade Pvt. Ltd., Plot No.1, City Centre, Sector-13, Dwarka, New Delhi.

CONDITIONS

1. Access road for fire tenders movement all around the building shall be kept free from any hindrance.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S RELIANCE AMBIT TRADE PVT. LTD., Commercial Plot No.1, City Centre, Sector-13, Dwarka, New Delhi-110045.
2	Type of Occupancy	Mercantile
3	Type of case	Renewal (Three Basements, Ground Plus three upper floors)
4	Details of previous NOC	F6/DFS/MS/Mercantile/2014/SZ/SZ/1509 dated 3.12.2014
5	Fire safety directives letter No	F6/DFS/MS/BP/2008/613 dated 29.2.2008 & F6/DFS/MS/BP/2012/2955 dated 13.8.12
6	Date of inspection	14.5.2018
7	Name of the inspecting Officers	M K Chattopadhyay DO (S/W) & Satpal Bhardwaj ADO (Dwarka)
8	Name and designation of officers from the building side	Sh. Sunil Kumar Sharma (EGM) & Sh. Vijay Kumar (Mall Manager)
9	Year of construction	2014
10	Applicant's letter No.	Nil Dated 12.4.2018

Three Basement, Ground + Three upper Floors

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ letter dated 3.12.2014	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	20 Mtrs.	MR
	2) Gate width	6 Mtrs.	6 Mtrs.	MR
	3) Width of internal road	6 Mtrs.	6 Mtrs.	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	9 Nos.	9 Nos.+ 1 Ramp	MR
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	2 Mtrs.	MR
	2. basements	1.5 Mtrs - 2 Mtrs.	2.00/1.8./1.50 Mtrs.+1 Ramp 7.5 Mtrs. (Two Way)	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace			
		3 Nos.	3 Nos. Ground to Terrace 1 No. Basement to Terrace	MR
	e. Width of corridor			
		2.40 Mtrs.	2 to 5 Mtrs.	MR
	f. Door size			
		1.5 Mtrs.	1.5 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Removed	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
5	Fire Extinguishers			
	total numbers	120 Nos.	121 Nos.	MR
	Types	CO2&ABC	CO2,ABC,DCP,WCO2	MR
	ISI marking	Required	Provided	MR

	total numbers on each floor	Nos.) GF 6 Nos. & 1st to 3rd floor (4 Nos.0	Provided	MR
	Length of Hose reel hose	30 Mtrs.	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Smoke / Heat	Provided	MR
	location of Main Panel	Ground floor	Ground floor	MR
	location of Repeater panel	Required	Provided at ground floor	MR
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Appropriate Place	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	Size of riser/down-corner	150 mm	Provided	MR
	Number of Hydrants per floor	4 Nos. each floor	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	12 Nos.	12 Nos.	MR
	hose box	Required	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2850 LPM	Provided	MR
	b. Head of main pump	70 Mtrs.	Provided	MR
	c. Number of main pumps	2 Nos.	Provided	MR
	d. jockey pump out put	2 X 180 LPM	Provided	MR
	e. jockey pump head	70 Mtrs.	Provided	MR
	f. Standby Pump output	1 X 2850 LPM	Provided	MR
	g. Stanby Pump head	70 Mtrs.	Provided	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	i. pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	At ground level	1,00,000 Ltrs.	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	10 KL	20 KL	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided	MR
	b. pressurization of lift lobby	Required	Provided	MR
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	DG Set Provided	MR

18	Refuge Area.	MR		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	Required	Provided	MR
	c. PA system Panel	Required	Provided	MR
	d. Battery backup	Required	Provided	MR
	e. Building floor plans	Required	Provided	MR
20	Special Fire Protection System for Protection of special Risks, if any:	CO2 trolley near HT, LT panels.	Provided	MR

Shortcomings vide letter no. F6/DFS/MS/2018/SZ/57 dated 4.1.2018 found rectified. ✓

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of FSC Issued vide letter no. F6/DFS/MS/Mercantile/2014/SZ/1509 dated 3.12.2014 is recommended.

Accordingly DFA is put up for your approval and signature please.

M.K. Chattopadhyay
DO (South West)

[Signature]
16/5/18

S.P. Bhardwaj
ADO (Dwarka)

[Signature]
15/4/18

306/DO/SW
16/5/2018
1401/DFS/SZ
17/5

DCA (S2)

danf
16/5

Chd 22

m.scell

FT 100.
U
17/5

FT is put up for signature plan

Chd 52

m.scell

U
24/5

[Signature]
18/5/18

