

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO. F.6/DFS/MS/NDZ/2018/ 1208

Dated:- 23/5/2018

FIRE SAFETY CERTIFICATE

Certified that the M/S Aggarwal Fun City Mall at Plot No. 29-31, CBD Shahdara Delhi, comprised of **two basements, ground plus two upper floors** owned/occupied by Aggarwal Plaza Pvt. Ltd. was granted FSC by this department vide letter No. F6/DFS/MS/2015/NDZ/1626 dated 08-09-2015. The premises was re-inspected by the officer concerned of this department on 07-05-2018 in the presence of **Sh. Sunil Kumar Jain** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and that the premises is fit for occupancy **class -F Mercantile Building** with effect from ~~23/5/18~~ for period of **three** years in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 23/5/2018 at New Delhi

23/5
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service
Ph- 011-23412225
OIC SM

Copy to:- 1. Medical Officer of Health (Health Department),
NDMC, Palika Kendra, New Delhi.

2. The licensee
Sh. Sunil Kumar Jain
M/S Aggarwal Fun City Mall Plaza Pvt. Ltd.
Plot No. 29-31, CBD, Shahdara Delhi.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

B1 G + Two upper floor

INSPECTION REPORT

- 1. Name & address of the building : Aggarwal Fun City Mall at plot No. 29-31, CBD Shahdara, Delhi
- 2. Type of occupancy : Mercantile
- 3. Type of Case : Renewal
- 4. Details of Previous NOC : F6/DFS/MS/2015/NDZ/1626 Dated- 08/09/2015
- 5. Fire Safety directives No : F6/DFS/MS/BP/2005/1448 dated - 08/07/05
- 6. Date of Inspection : 07/05/2018
- 7. Name of the Inspecting Officers: : Sh. Sunil Chawdhary , Dy.CFO (NDZ) & F. Brown (D.O East)
- 8. Name of the designation of Officer
from the building side : Sunil Kumar Jain
- 9. Year of Construction : 2005
- 10. Applicant's letter No : 6617, Dated 25-04-2018.

MALL

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement as Per NBC	Provided at Site	Remarks MR/NMR
1	Access to building	Mall		
	Road width	12 mtrs	26 mtrs.	MR
	Gate width	4.5 mtrs.	5 mtrs.	MR
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits	Mall		
	a. Number of Staircases			
	Upper Floor(Gr & 01 floor)	05 Nos.	05 Nos.	MR
	Basement	05 Nos	05Nos.+1 Ramp	MR
	B. Width of Staircases			
	Upper Floor	1.5 M	1.5 M	MR
	Basement	1.5 M	1.5 M	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	Required	Provided	MR
e. No. of continuous staircases to terrace	2 Nos.	2 Nos.	MR	
g. Width of Corridor	2.5 Mtr.	2.5 Mtr.	MR	
h. Door Size	1.5 mtr.	1.5 mtr.	MR	
3	Compartmentation.	Mall		
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	2 hrs.	2 hrs.	M/R
	Water curtain	N/A	N/A	N/A
	Fire Dampers	Required	Provided	MR
4	Smoke Management System.	Mall		
	Basement	30a/c per hour	Provided	MR
	Upper floor	12 a/c per	Provided	MR

5.	Fire Extinguisher	Restaurant		
	Total numbers	60 Nos.	60 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	Provided	MR
6	First-aid-Hose Reels.	Restaurant		
	Total numbers of each floor	6 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.	Restaurant		
	Type of detectors	Heat/Smoke	Provided	MR
	Location of main panel	Control Room	1 st Basement	MR
	Location of repeater panel	Security Room	Provided	MR
	Alternate source of power	Battery & DG SE	Provided	MR
	Hooters's location	Different Location	Different Location	MR
8	MOEFA	Restaurant	Required	Provided
				MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants	Mall		
	size of riser/down-comer	100 mm	provided	MR
	Number of hydrants per floor	06 Nos.	Provided	MR
	Hose Box	06 Nos.	Provided	MR
12	Yard Hydrants.	Mall		
	Total number of hydrants	3 nos.	3 nos.	MR
	Hose Box	3 nos.	3 nos.	MR
13	Pumping Arrangements.	Mall		
	1) Ground Level	Required	Provided	MR
	a) Discharge of main Pump	2280 LPM	2280 LPM	M/R
	b) Head of Main Pump	60 Mtrs.	60 Mtrs.	M/R
	c) Number of main pumps	01 nos.	01 nos.	M/R
	d) Jockey pump out put	450 LPM	450 LPM	M/R
	e) Jockey pump head	60 Mtrs.	60 Mtrs.	M/R
	f) Standby pump out put	2280 LPM	2280 LPM	M/R
	g) Standby pump Head	60 Mtrs.	60 Mtrs.	M/R
	h) Auto Starting /Manual stopping	Auto	Provided	M/R
	2) Terrace Level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of the Pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto Starting of pump	N/A	N/A	N/A

14	Captive Water Storage for Fire Fighting.	Mall		
	1) Underground tank capacity	20,000ltr	20,000ltr	M/R
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Overhead Tank capacity Restaurant	25,000 Liters	25,000 Liter	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Mall		
	a) Pressurization of Lift Shaft	Required	Provided	MR
	b) Pressurization of Lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Firemen's grounding switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR
17	Standby power supply	Required	1000 KVA	MR
18	Refuge Area.	Mall		
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room	Mall		
	Detector system panel	Required	Provided	MR
	Flow switch panel	Required	Provided	MR
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules, The Rules the FSC issued vide letter . F6/DFS/MS/2015/NDZ/1626 dated 08.09.2015 renewal under the rule 35 of the Delhi Fire Service Rule 2010/ is recommended for FSC please.

Signature of the Inspecting Office
 Name Sunil Chawdhary
 Designation DY. CFO(NDZ)

Signature of the Inspecting Officer
 Name F. Brown
 Designation Div Officer

CB/HQ

M.scell FT/10-
 U 23/5

F.t. letter is put up for inspection
 please in 23/5
 M.scell U