

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZI/ 1075

Dated: 16/5/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Anglo Indian Public School, E-20/8A, St. No.-6, Subhash Vihar, North Ghonda, Delhi-53, running on ground plus one upper floor comprised of ground plus two upper floors owned / occupied by Anglo Indian Public School. The school building was inspected by the officer concerned of this department on 26/04/18 in presence of Sh. Priya Kasana, Principal of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 16/5/18.....for a period three year, subject to conditions printed overleaf.

Issued on 16/5/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,
The Manager
M/s Anglo Indian Public School,
E-20/8A, St. No.-6, Subhash Vihar, North Ghonda,
Delhi-53.

Copy to:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi- 110053.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

000000

M/2

1. Name & address of the building : Anglo Indian Public School, E-20/8A, St. No.-6, Subhash Vihar, North Ghonda, Delhi-53.
2. Building is comprised of : G+2 (running on G+1 floor only)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC letter : N/A
6. Fire Safety circular No (Circular No. 262-362 dated 17/01/05)
7. Date of Inspection : 26/04/18
8. Name of the Inspecting officers : ADO Omprakesh
9. Name and designation of Officer from the building side : Sh. Priya Kasana (Principal)
10. Year of Construction : 2007
11. Applicant's letter No : Nil Dated – 16/04/2018

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per D.O.E <small>Circular Dt 17.01.05</small>	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	08 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	1.50 mtr	1.07 m & 1.0 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	01 no.	02 no.	MR
	d. No. of continuous staircases to terrace	1.5 m	1.5 m	MR
	e. Width of Corridor	1.0 m	1.5 m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	220LPM	220LPM	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltrs	2500 Ltrs	MR
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

Om Prakash
26/4/18

Signature of the Inspecting Officer
Name : - Om Prakash
Designation : - ADO (Shahdara)

DO (East) *Submitted for approval*

for
28/4

DCFO/NDZ *[Signature]*

520/CG/NPZ
28/4/18

C. F. O. M. S. C. E. N
FTM.
4/5.

Sir, f. T letter is put up for your kind signature please.

C. F. O. (NDZ)
M. S. C. E. N *4/5.*

Om Prakash
10/5