

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/NDZ/2018/ 1078

Dated: 16/5/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Plato Public School, I. P. Extension, Patparganj, Delhi- 110092, comprised of Ground plus three upper floors owned / occupied by Plato Public School was issued FSC vide letter No. F6/DFS/MS/School/2014/NDZ/859 dated 14/07/14. The school building was re-inspected by the officer concerned of this department on 04/05/18 in the presence of Smt. K. Dhawan Director of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. 262-362 Dated: 17/01/05 Issued by Direct of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 16/5/18.....for a period three year, subject to conditions printed overleaf.

Issued on.....16/5/18.....at New Delhi by

W
10/5
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director,
Plato Public School, I.P. Extension,
Patparganj, Delhi- 110092.
2. The Director of Education
GNCT of Delhi, Old secretariat,
Delhi- 110054.

olc
h

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

Docent

1. Name & address of the building : Plato Public School, I.P. Extension, Patparganj, Delhi -92.
2. Building is comprised of : G+ 3 upper Floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2014/NDZ/859 dated: 14/07/14
6. Fire Safety direction letter No : Old requirement (Circular No.262-362 dated17/01/05)
7. Date of Inspection : 04/05/2018
8. Name of the Inspecting officers : DO Francis Brown.
9. Name and designation of Officer from the building side : K. Dhawan (Director)
10. Year of Construction : 2004-05
11. Applicant's letter No : PPG/PG/1906/18 Dated - 12/04/2018

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per circular(262-362 dtd17/01/05)	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	15 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.4 m each	MR As accepted earlier
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	02 nos.	MR
	e. Width of Corridor	1.5 m	1.7 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	12 nos.	16 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 nos.	01 nos.	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m 5 mm	30 m 5 mm	MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 01 nos. 01 nos.	100 mm 01 nos. 01 nos.	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main Pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump Head Auto Starting /Manual stopping Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of the Pump Power supply Auto Starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40 m Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40 m Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 5000 Liters	N/A N/A N/A N/A 10000 Liters	N/A N/A N/A N/A MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

The Fire safety Certificate issued vide letter no. F6/DFS/MS/School/2014/NDZ/859 dated 14/07/14 has grant under circular No. 262-362 dated 17/01/05 is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

Francis Brown
4/5/15

Signature of the Inspecting Officer
Name: Francis Brown
Designation: DO (East)

522/CFD/NDZ
4/5/15

DCFO (NDZ) *[Signature]*

CFP. M.Scell *[Signature]*
4/5

F.T. letter is prepared and put up for biscuits phn.

CFP/NDZ M.Scell *[Signature]*
4/5