

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SCHOOL/WZ/2018/ 1214

Dated: 24/5/2018

FIRE SAFETY CERTIFICATE

Certified that the **Presidium Sr. Sec. School, Located at PS-2, C-3 block, Ashok vihar Ph-II, Delhi - 110052. (A, B & C Blocks)** comprised of 03 Blocks (BL-A=G+ 3UF)(BL-B= B+G+3UF) & (BL-C=B+Stilt+G+3 Upper Floor Only) was issued FSC vide Letter No. F6/MS/DFS/School/2015/WZ/289 Dated 02-03-2015 The premises was re inspected by the officer concerned of this department on 02-05-2018 in the presence of **Mr. Karan Singh Authorized Signatory** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC and that the premises is fit for occupancy class "Educational" Group B with effect from 24/5/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24.5.18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, **Presidium Sr. Sec. School, Located at PS-2, C-3 block, Ashok vihar Ph-II, Delhi - 110052.**
2. **Directorate Of Education Old Secretariat Delhi – 110054**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws 1983.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **Presidium Sr. Sec. School, Located at PS-2, C-3 block, Ashok vihar Ph-II, Delhi - 110052.**
2. Type of Occupancy : **Educational 03 Blocks (BL-A=G+ 3UF)(BL-B=B+G+3UF) & (BL-C=B+Stilt+G+3 Upper Floor Only)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/MS/DFS/School/2015/WZ/289 Dated 02-03-15**
5. Fire Safety directives Letter No. : **NBC**
6. Date of inspection : **02-05-2018**
7. Name of the Inspecting Officer : **Udaiyir Singh, ADO (WP)**
U D Singh
8. Name and designation of Officer
from the building side : **Mr. Karan Singh Authorized Signatory**
9. Year of Construction : **2004-05**
10. Applicant's letter No. : **Pre/av/april/2018/477 Dated -09/04/2018**

No. of Students=3500
No. of class rooms=88
Plot area=8118m ²
Covered area=6000m ²


S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	09 mtr	MR
	• Gate width	5.0 mtr	5mtrs	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-A=2 BL-B=2 BL-C=2	BL-A=2 BL-B=2 BL-C=2	MR
	• Basements	BL-B&C=2 each	BL-B=2 BL-C=2	MR
	b. Width of staircases			
	• Upper floors	1.5mtrs each	A- BL=1x128cm&1x145cm B- BL=2x125cm C- BL=2x148cm	MR Old case)
	• Basements	1.5m & 1m Each block	BL-B=2x144cm BL-C=2x150cm	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1.0 mtr	110 cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	72 nos. ABC & CO ₂ ISI marked	75 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	4 inch dia Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	2 Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pum 	NA NA NA NA NA NA NA NA NA NA NA 900 lpm & 180 lpm 50M Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity 	150000 ltrs	Required	MR

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/MS/DFS/School/2015/WZ/289 Dated 02-03-2015** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer

Name Uday Vir Singh
Designation ADO (WP)


Signature of the Inspecting Officer

Name Sh. Mohesh Verma
Designation D.O/W


~~Dy. ADO (WZ)~~

~~CFO West~~
~~5/5/18~~

FT PLS

D.O/W F.T. is put up for signature please.

~~CFO (West)~~
~~2/5/18~~


25/5/18