

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI



No. F6/DFS/MS/EH/WZ/2018/1177

Dated: 22/05/18

FIRE SAFETY CERTIFICATE

Certified that **PULSE RESTAURANT** (A Unit of Nanak Food) located at A-5, 1st floor, Vishal Enclave, Rajouri Garden, New Delhi-110027 in a building comprised of Ground + 2 Upper Floors owned/occupied by PULSE RESTAURANT was issued FSC vide Letter No. F6/DFS/MS/EH/2015/WZ/658 dated 01/05/2015. The premises was re inspected by the officers concerned of this department on **11-05-2018** in the presence of **Sh. Anudeep Narang (Owner)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 22/05/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...22/05/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.


Copy to:

Sh. Anudeep Narang (Owner)
PULSE RESTAURANT (A Unit of Nanak Food)
A-5, 1st floor, Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : PULSE RESTAURANT (A Unit of Nanak Food) located at A-5, 1st floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2015/WZ/658 dated 01/05/2015
5. Fire Safety directives letter No. : F6/6/TMS/inspection/2004/106 dated 04/04/2005
6. Date of inspection : 11/05/2018
7. Name of the Inspecting Officers : Divisional Officer Mukesh Verma
8. Name and designation of officers
- From the building side : Sh. Anudeep Narang (Owner)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : Form 'J'

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtrs	30 mtr	M/R
	• Gate width	NA	On main road	NA
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R
	• Basement	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	N.R. as per 2005circular	115 cm & 89 cm	M.R (being old case)
	• Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	• Fire check door	N.A.	N.A.	N.A.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	required	Provided	M.R
	e. Width of Corridor	Halls only	Halls only	M.R
	f. Door size	2 mtr	102 cm & 120 cm	M.R. (being old case)
3.	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	M.R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10	14	M.R
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	M.R
	<ul style="list-style-type: none"> • IS marking 	ISI marks	Provided	M.R
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	M.R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	M.R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> • Location of Main Panel 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> • Alternate source of power 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> • Hooter's Location 	N.R.	N.R.	N.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N.A.
	<ul style="list-style-type: none"> • Upper Floor 	N.R	Provided	M.R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N.R	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	M.R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	M.R
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/R	N/R	N/R
	<ul style="list-style-type: none"> • Hose Box 	N/R	N/R	N.R.

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	N.R.
	➤ Head of Main pump	N/R	N/R	N.R.
	➤ Number of main pumps	N/R	N/R	N.R.
	➤ Jockey Pump out put	N/R	N/R	N/R
	➤ Jockey pump head	N/R	N/R	N/R
	➤ Standby pump out put	N/R	N/R	N.R.
	➤ Standby pump Head	N/R	N/R	N.R.
	➤ Auto Starting/Manual stopping	N/R	N/R	N/R
	➤ Pump Hose Access	N/R	N/R	N/R
	Terrace level			
	➤ Discharge of pump	180 LPM 450 LPM	Provided	M.R
	➤ Head of the pump	30 mtr	Provided	M.R
	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.R.	N.R.	N.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	5, 000 ltr	Provided	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N/R	N/R	N.R.
	➤ Location	N/R	N/R	N.R.

19.	Fire Control Room			
	➤ Detector System Panel	N/R	N/R	N.R.
	➤ Flow Switch Panel	N/R	N/R	N.R.
	➤ PA system Panel	N/R	N/R	N.R.
	➤ Batter backup	N/R	N/R	N.R.
	➤ Building Floor plans	N/R	N/R	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F6/DFS/MS/EH/2015/WZ/658 dated 01/05/2015 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer *Mukesh 15/5/18*
 Name Mukesh Verma
 Designation DO (West)

Dy CFO (WZ)

[Signature] 16/5/18

CFO West by 21/5/18 FT PL

DO/W F.T./FSL is put up for signature please.

CFO (West) 22/05/18

Mukesh 22/5/18

MV