

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2018/wz/ EH/1157

Dated: 21/05/2018

FIRE SAFETY CERTIFICATE

Certified that the **Backyard Restaurant (A unit of Slur Hospitality)** located at **49, GF, North west Avenue, Punjabi Bagh Extension, New Delhi** in a building comprised of (Ground + 3 floors) was issued FSC vide Letter No F6/DFS/MS/WZ/2014/EH/1345 Dated 28/10/2014. The premises was re inspected by the officers concerned of this department on **02-05-2018** in the presence of Mr. Manoj and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Mercantile & Assembly Building" Group F & Group D with effect from 21/05/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/05/18 .. at New Delhi by.

(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:

1. Backyard Restaurant (A unit of Slur Hospitality), 49, GF, North west Avenue, Punjabi Bagh Extension, New Delhi.
2. The DHO, SDMC, Public Health Department, West Zone, Vishal Enclave, Rajori Garden, N. Delhi-110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

(Signature)
Rajni
EP/MS/2018

INSPECTION REPORT

1. Name & address of the building : **Backyard Restaurant (A unit of Slur Hospitality), 49, GF, North west Avenue, Punjabi Bagh Extension , New Delhi.**

1. Type of Occupancy : Assembly
 2. Type of Case : Renewal (Ground floor only)
 3. Details of previous NOC: F6/DFS/MS/WZ/2014/EH/1345 Dated 28/10/2014
 4. Fire Safety directives letter No. : Nil
 5. Date of inspection : 02-05-2018
 6. Name of the Inspecting Officers : DO (West) & ADO (MN)
 7. Name and designation of officers

From the building side : Mr. Manoj

8. Year of Construction : Old Construction
 9. Applicant's letter No. : Nil dated- 16/04/2018

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	M/R
	• Gate width	4.5 mtr	On Road	M/R
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N.R.	N.R.	N.R.
	• Basement	N.R.	N.R.	N.R.
	b. Width of staircases			
	• Upper Floors	N.R.	N.R.	N.R.
	• Basement	N.R.	N.R.	N.R.
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	N.R.	N.R.	N.R.
	e. Width of Corridor	N.R.	N.R.	N.R.
	f. Door size	2 m & 1m	2m, 1m, 76cm & 91cm	M.R.
3.	Compartmentation.			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.

4.	Smoke Management System.			
	• Basements	N.R.	N.R.	N.R.
	• Upper floors	N.R.	N.R.	N.R.
5.	Fire Extinguishers			
	• Total numbers	05	08	M.R
	• Types	CO ₂ , Water CO ₂	Provided	M.R
	• IS marking	type ISI marked	Provided	M.R
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R.	N.R.	N.R.
	• Location of Main Panel	N.R.	N.R.	N.R.
	• Location of Repeater Panel	N.R.	N.R.	N.R.
	• Alternate source of power	N.R.	N.R.	N.R.
	• Hooter's Location	N.R.	N.R.	N.R.
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	N.R.	N.R.	N.R.
10.	Automatic Sprinkler system			
	• Basement	N.R.	N.R.	N.R.
	• Upper Floor	N.R.	N.R.	N.R.
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	M.R
	• Number of hydrants per floor	1	Provided	M.R
	• Hose Box	1	Provided	M.R
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R
	➤ Head of the pump	30 mtr	Provided	M.R
	➤ Power supply	required	Provided	M.R
	➤ Auto Starting of pump	required	Provided	M.R
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	N.R.	N.R.	N.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R

18.	Refuge Area			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R	N.R	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/2014/EH/1345 Dated 28/10/2014 .renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- The terrace was found sealed by MCD but the pump was seen from the terrace of nearby property and adequate water pressure was found at ground level.

Signature of the Inspecting Officer *[Signature]* 11/5/18

Name *Uday Vir Singh*

Designation *ADD O/W P*

Signature of the Inspecting Officer *[Signature]* 11/5/18

Name *Sh Mukesh Verma*

Designation *DO/W*

[Signature]
 Dy. CFO (N) *[Signature]*
 CFO West *[Signature]*
 18/8/18

[Signature]
 16/5/18

recommended F.T letter is put up