

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: 66/08/08/1/2/1161

Dated: 22/5/18

FIRE SAFETY CERTIFICATE

Certified that the building of **Blooming Buds Public School** Located at **1st & 2nd Floor, B-Block, New Moti Nagar, New Delhi – 110027** in a building comprised {One Block = Ground (**Religious function**) + 03 Upper Floors, owned and occupied by **Blooming Buds Public School** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education/NBC Part IV and verified by the officers concerned of Fire Service on 30-05-2014 in the presence of Miss. Rashmi Gandhi (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from ..22/5/18..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.
Issued on22/5/18..... at New Delhi.

(Atul Garg)
Chief Fire officer
Delhi Fire Service.

Copy to:-

1. The Principal, Blooming Buds Public School, B- Block, New Moti Nagar, New Delhi – 110027.
2. Director of Education, Old Secretariat, Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
9. 3rd floor shall not be used for any purpose.

INSPECTION REPORT

1. Name & address of the building: **Blooming Buds Public School**, Located at, **1st & 2nd Floor, B- Block, New Moti Nagar, New Delhi – 110027.**
2. Type of Occupancy : Educational {One Block = Ground (**Religious function**), **1st & 2nd Floors(For School) }**
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-11
6. Date of inspection : 01-05-2018
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Miss. Rashmi Gandhi (Principal)
9. Year of Construction : 1967
10. Applicant's letter No. : BBPS/B-37/JAN./2018/2011 dated 20-03-2018

Area of School -4250 sqf
Covered Area -4250sqf
Class Rooms – 14
Total Students – 409

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 7 m Provided On Road NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.5m, NA 	<ul style="list-style-type: none"> 1x92cm (Up to 3rd F) 1x165cm(Up to 1st F) 1x108cm(1st to 2nd F) NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • No of continuous staircase to terrace 	<ul style="list-style-type: none"> Required 	<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • Width Of Corridor 	<ul style="list-style-type: none"> 1.5 m 	<ul style="list-style-type: none"> 160cm 	<ul style="list-style-type: none"> MR
	f. Door Size			
	<ul style="list-style-type: none"> • Door Size 	<ul style="list-style-type: none"> 1 m 	<ul style="list-style-type: none"> 101cm Provided 	<ul style="list-style-type: none"> MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	7 nos.	8 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm NA	Provided	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1 NA	Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	Required: NA	provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 Litres	5,000 litres Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings Nil as noted at serial numbers

~~ADP~~
~~11/5/18~~
 Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADP/WP

Signature of the Inspecting Officer
 Name
 Designation

ADP/WP
7/5/18
~~Dy. Commr~~
~~8/5/18~~
CFD West
10/5/18

ADP/WP
 Sir AT letter is put up for
 sign ple.
10/5/18
11/5/18