

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2018/SZ/ 1155

Dated: 21/05/18

FIRE SAFETY CERTIFICATE

Certified that **Burger King Restaurant** located at Shop No-2 & 3, 2<sup>nd</sup> floor of Select City Walk Mall, A-3, District Centre, Saket, New Delhi-110017 comprised of Basement, Ground plus two upper floors owned/occupied by Burger King India Private Limited. The restaurant is running at 2<sup>nd</sup> floor was issued FSC by this department vide letter No. F6/DFS/MS/EH/2014/SZ/1348 dated 28-10-2014. The premises was re-inspected by officer concerned of this department on 04/05/2018 in the presence of Mr. Mani (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class "**Assembly, Group-A**" (Eating House) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/05/18 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. Auth. Signatory M/s Burger King India Pvt. Ltd at Shop No- 2&3, 2<sup>nd</sup> Floor, Select City Walk Mall, Saket, New Delhi-110017
2. The Addl. Comm. of Police (Lic.), First Floor, P.S. Defense Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.



## INSPECTION REPORT

1	Name & Address of the Building	M/s Burger King at Shop No-2 & 3, 2 <sup>nd</sup> Floor, Select City Mall, Saket, New Delhi-110017		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Basement, Ground + 02 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2014/SZ/1348 Dated 28-10-2014		
6	Fire Safety Directives Letter No	N/A		
7	Date of Inspection	04-05-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Mani (Manager)		
10	Year of construction	2007   Restt running at 2 <sup>nd</sup> floor of the building.		
11	Applicant letter No.	Nil dated 09-04-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	<b>F6/DFS/MS/Mall/SZ/2018/585 dated 04-04-2018</b>		
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Restt located in Mall Bldg	As above	MR
			As above	-NA-
			As above	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>	Provided & Maintained by Building Management		
	➤ Upper floors.	02 Nos	Provided near Restt.	MR
	➤ Basement floor.	-NA-	As above	-NA-
	<b>b) Width of Staircase</b>	Provided & Maintained by Building Management		
	➤ Upper floors	1.5 mtr	1.52m & 1.16m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>	Provided & Maintained by Building Management		
	➤ Fire check door	Required	As above	MR
	➤ Pressurization	Required	As above	MR
	<b>d) No. of continuous staircase to terrace</b>	Required	As above	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	2.0m	Open front more than 12m & 1.75m	MR
3	<b>Compartmentation.</b>	Provided & Maintained by Building Management		
	• Fire check door.	Required	As above	MR
	• Sealing of electrical shafts.	Required	As above	MR
	• Fire rating of shaft door.	Required	As above	MR
	• Water curtain	Required	As above	MR
	• Fire dampers.	Required	As above	MR
4.	<b>Smoke Management system.</b>	Provided & Maintained by Building Management		
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Restt. premise	12 ACPH	Exhaust fan provided	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	Provided	MR
	• Types	ABC / CO2	ABC, CO2 & Foam	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>	Provided & Maintained by Building Management		
	• Total numbers on each floor.	One	Provided near Restt.	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

M/s Burger King at Shop No-2 & 3, 2<sup>nd</sup> Floor, Select City Mall, Saket, New Delhi








19.	<b>Fire Control Room.</b>	Provided & Maintained by Building Management		
	• Detector system panel.	-NA-	As above	-NA-
	• Flow switch panel.	-NA-	As above	-NA-
	• PA system panel.	-NA-	As above	-NA-
	• Battery backup.	-NA-	As above	-NA-
	• Building floor plan.	-NA-	As above	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	As above	-NA-

The fire protection system provided in the building/ premises were tested, checked at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter dated 05.04.2018 found complied.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/EH/2014/SZ/1348 dated 28/10/2014, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Mehmood  
 Design: ADO (SJ)

M/s Burger King at Shop No-2 & 3, 2<sup>nd</sup> Floor, Select City Mall, Saket, New Delhi

*Put up with date under your signature.*

DO (SD)

*Anilash*  
11/5/18

*DO/SP* Re-submitted

*Mehmood*  
11/5/18 (ADO (SJ))

*DO (SD)*

*Anilash*  
14/5/18

*DO/SP*

*DO/SP*  
16/5

F 7/187.

*DO/SP*  
17/5



1416/CFSC  
18/5-02/18

*DO/SP*

m.s cell

*Signature Please*