

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018/ *W2/1089*

Dated: *16/5/18*

FIRE SAFETY CERTIFICATE

Certified that **Invitation Ceremonial** located at **B-52, G.T.K Road Indl. Area, Delhi-110033** comprised of **ground and two upper floors** owned/ occupied by **Invitation Ceremonial** was granted fire safety certificate vide letter no. **F6/DFS/MS/2014/EH/WZ/961 dated 30/07/2014**. The premises was re-inspected by the officer concerned of Fire Service on 01/05/2018 in the presence of **Sh. Subhash Kakkar** and observed that all the fire prevention and fire safety arrangements as provided in the premise found good working condition. The premise have therefore deemed complied with the fire prevention and fire safety measures in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building / premise is fit for occupancy class "Assembly Group D-5" with effect from ~~16/5/18~~ for a period of **three years** in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on *16/5/18*..... at New Delhi by

(Signature)
(Atul Garg)
Chief Fire Officer
Ph: 01123414250
(Signature)

Copy to : -

1. Sh Subhash Kakkar, Invitation Ceremonial, B-52, , G.T Road Indl. Area, Delhi-110033.

N/21

INSPECTION REPORT

1. Name & address of the building : Invitation Ceremonial, B-52, G.T.K. Road Indl. Area, Delhi-110033.
2. Type of Occupancy : Assembly – (G+02 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2014/EH/WZ/961 dated 30/07/2014
5. Fire Safety directives letter No : Renewal
6. Date of inspection : 01/05/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Subhash Kakkar
9. Year of Construction : 2004
10. Applicant's letter No. : Nil dated Nil, Dairy No. 4842 dated 23/03/2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	9m approx	MR
	• Gate width	2m x 02	02m x 02(old case)	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m each	1.80m & 1.50m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	02	02	MR	
e. Width of Corridor	NA	NA	NA	
f. Door Size	2.0m x 2	2.0m x 02	MR	
3	Compartmentation.			

R

M/22

	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	17nos	18	MR
	• Types	ABC & Co2	W. Co2 - 04 Co2 - 04 ABC-10	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	P	NA
10	Automatic Sprinkler System.			
	• Basement	R	PF	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA

(Handwritten mark)

N/23

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900LPM	900lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15000 ltr	15000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA

A

11/24

	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided inverter	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 961 dated 30.07.2014 under rule 35 of the Delhi Fire Service Rules 2010.

11/3/15

Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN

~~Dy CFO/W2~~
~~CFO west~~
 01/05/17
 F.P.S.
 As approved, F.T. letter is put up for your signature please
 11/4/15
 CFO/W2