

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2018/SZ/ 1146

Dated: 18/5/18

FIRE SAFETY CERTIFICATE

Certified that the Shree Venkateshwar International School, Sector-18, Dwarka, New Delhi-110075, comprised of Basement, ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/432 dated 25.3.2015. The said premises was re-inspected by the officer concerned of this department on 21.4.2018 in the presence of Sh. Salander Solanki (Chairman) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and that the school building is fit for occupancy class B "Educational building" with effect from ~~18/5/18~~ 18/5/18 for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on 18/5/18 at New Delhi by


(Vipin Kental)
OC Chief Fire Officer
Delhi Fire Service


Copy to:-

1. Director (Education), G.N.C.T. of Delhi, Old Secretariat, New Delhi-110054.
2. Authorized Signatory, Shree Venkateshwar International School, Sector-18, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Shree Venkateshwar International School, Sector 18, Dwarka, New Delhi-110075.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal (B + Ground +3 Upper Floors)	
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/432 dated 25.3.2015	
5	Fire safety directives letter No	F6/DFS/MS/2007/1542 dated 8.6.2007	
6	Date of inspection	21.4.2018	
7	Name of the inspecting Officers	S.P. Bhardwaj ADO Dwarka	
8	Name and designation of officers from the building side	Sh. Shalender Solanki (Chairman)	
9	Year of construction	2007	
10	Applicant's letter No.	SVIS/Admn./2017-18/530 dated 10.3.2018.	(Basement + ground & three upper floors.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement/ letter dated 8.6.2007	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	6 Mtrs.	Provided	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	6 Nos.	6 Nos.	MR
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs.	MR
	2. basements	1.5 Mtrs.	1.5 Mtrs.	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	4 Nos.	4 Nos.	MR
	e. Width of corridor	1.50 Mtrs.	1.80 Mtrs.	MR
	f. Door size	1 Mtr.	1.05 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 ac charge 12 ac charge	Exhaust fans provided	MR
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	4 Nos. at each floor	24 Nos.	MR
	Types	CO2 & ABC	CO2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Two	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Provided in basement	MR
	location of Main Panel	Ground Floor	Provided	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	DG Set 160 KVA	MR
	hooter's location	Appropriate Places	Near Stairecases	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	100 MM	MR
	Number of Hydrants per floor	Two	Two	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	2 Nos.	2 Nos.	MR
	hose box	Required	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 Lpm	Provided	MR
	b. head of the pump	30 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	50000 Ltrs.	50000 Ltrs.	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	15000 Ltrs.	20000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	provided	MR
	e. Lift signage	Required	Provided	MR

N/17

	Required	DG Set KVA	MR
17 Standby power supply			
18 Refuge Area.	Not Required		
total area location			
19 Fire control room			
a. detector system Panel	N/A	N/A	N/A
b. Flow switch Panel	N/A	N/A	N/A
c. PA system Panel	N/A	N/A	N/A
d. Batter backup	N/A	N/A	N/A
e. Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special risks: CO2 Fire Extinguisher provided near electric Panel	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements, renewal of FSC issued vided letter no.F6/DFS/MS/School/2015/SZ/432 dated 25.3.2015 is recommended.

Accordingly DFA is put up for your approval and signature please.

8.5.18
3/4
460/DO(S2)
dt. 07/05/18

S.P. Bhardwaj
ADO (Dwarka) 25/4/18

~~MSW~~

~~MSW~~ 21/5/2018

~~DCFO (S2)~~

~~MSW~~
9/5

1371/CF0 S2
11/5/18/5

CF0 S2 m.scell F 7/10.
11/5

FF is put up for signature please.

~~CF0/S2~~ m.scell 17/5

S.P. Bhardwaj
15/5/18