

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2017/SZ/ 1103

Dated: 1.6.18

FIRE SAFETY CERTIFICATE

Certified that Sai Vidya Niketan Public School located at D-Block, Hari Nagar Extn, Part-II, Badarpur, New Delhi-110044, comprised of Ground floor only was granted FSC by this department vide letter No. F.6/DFS/MS/2014/SZ/755 dated 19/06/2014. The school premises was re-inspected by officer concerned of this department on 06.04.2018 in the presence of Mr. Abhinav (Admin) and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the premises is fit for occupancy class **Educational**, Group-B (School) as above with effect from 1.6/18 for a period of **Three years** subject to compliance of the condition mentioned below.

Issued on 1.6/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to: -

1. The Principal, Sai Vidya Niketan Public School, D-Block, Hari Nagar Extn, Pt-II, Badarpur, New Delhi-110044
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	Sai Vidya Niketan Public School, D-Block, Hari Nagar Extn, Pt.-II, Badarpur, New Delhi		
2	Type of Occupancy	Educational 'Group-B' (School)		
3	Building Comprised of	Ground floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2014/SZ/755 Dated 19-06-2014		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17-01-2005		
7	Date of Inspection	06-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Abhinav (Admin)		
10	Year of construction	1998		
11	Applicant letter No.	SVNPS/2018/DFS/ dated 16-03-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	N/A	4 mtr	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	Required	4 No's	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First aid Hose-reels.			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

Sai Vidya Niketan Public School, D-Block, Hari Nagar Extn, Pt-II, Badarpur, New Delhi

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	N/A	N/A	N/A
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. 	N/A	N/A	N/A
	b) Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A

19.	Fire Control Room.	• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	01 ABC type fire extinguisher provided near electrical panel	MR	

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/2014/SZ/755 Dated 19.06.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
12/4/18

Signature of the Inspecting Officer
Name: R.N. Singh
Designation: ADO (BCP)

Sai Vidya Niketan Public School, D-Block, Hari Nagar Extn, Pt-II, Badarpur, New Delhi

DO (SD)

[Handwritten Signature]
16/4/18

[Handwritten Signature]

[Handwritten Signature]
16/4

class room door width to be mentioned.

CFO 12/4

Miscell

[Handwritten Signature]

[Handwritten Signature]
23/4

DCFSZ

1274/CFO S2
24/4/18

Sir necessary correction have been made in the inspection report & resubmitted.

[Handwritten Signature]

Miscell

[Handwritten Signature]
27/4

[Handwritten Signature]
24/4

A G. T. letter put up for Signature please