

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 1101

Dated: 16/5/18

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Co-Ed. Vidyalaya** located at Sector-2, R.K. Puram, New Delhi-110022, having two blocks each comprised of ground plus one upper floor, owned/occupied by Director of Education, Govt. of NCT Delhi have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Fire Service on 07.04.2018 in the presence of Ms. Vandana (Principal) of the school and that the building/premises is fit for occupancy class 'Educational' Group-B (School) as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 16/5/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to: -

1. The Principal, Sarvodaya Co-Ed. Vidyalaya, Sector-2, R.K. Puram, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya C-o-Ed. Vidyalaya, Sector-2, R.K. Puram, New Delhi-110022 (ID: 1719013)		
2	Type of Occupancy	Educational, "Group-B" (School)		
3	Building Comprised of	Ground + one upper floors (two blocks)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Vandana (Principal)		
10	Year of construction	Old Block-1963 & New Block-2014		
11	Applicant letter No.	2093/SCO-EDV/RK Puram II dated 13-03-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	• Upper floors.	02 each block	Provided	MR
	• Basement floor.	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	1.5 mtr	Old Bk-2m each New Bk- 1.70m each	MR
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	08 Nos	10 Nos	MR
	• Types	Co2 / ABC	ABC type	MR
	• ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

Sarvodaya Co-Ed. Vidyalaya, Sector-2, RK Puram, New Delhi-110022

19.	Fire Control Room.	• Detector system panel.	NA	NA	NA
		• Flow switch panel.	NA	NA	NA
		• PA system panel.	NA	NA	NA
		• Battery backup.	NA	NA	NA
		• Building floor plan.	NA	NA	NA
		20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
26/4/18

Signature of the Inspecting Officer
Name: R.N. Singh
Designation: ADO (BCP)

Sarvodaya Co-Ed. Vidyalaya, Sector-2, RK Puram, New Delhi-110022

DO (SD)

Aminder
1/5/18

Dy. BCP

1351/CR 82
2/5/15



Kap
2/5

CR 82

M.S. Cell

FT/101.

u
4/5

At B.T. letter is put up for signature please

CR 82p

M.S. Cell

u
25/5

Aminder
26/4/18