

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

NO.F6/DFS/MS/School/2018/SZ/ 1107

Dated: 16/5/18

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co-Ed. Sr. Sec. School, Sector-16A, Dwarka, NewDelhi-110078, comprised of ground plus one upper floor was issued fire safety certificate vide this department letter no. F6/DFS/MS/School/2014/SZ/1181 dated 12.9.2014. The said building was re-inspected by the officer concerned of this department on 3.5.2018 in presence of Sh. J R Meena (Principle) & Sh. Ashok Yadav (Estate Officer) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from... 16/5/18... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ... 16/5/18 ... at New Delhi by

16/5  
(Vipin Kental)  
Chief Fire Officer  
Say

Copy to:-


1. The Director (Education), GNCT of Delhi, old Secretariat, Delhi-110054.
2. Principal Govt. Co-Ed. Sr. Sec. School, Sector-16A, Dwarka, NewDelhi-110078.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Govt. Co-Ed Secondary School, Sector-16 A, Dwarka, New Delhi-110078.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (G+1)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/1181 dated 12.9.2014		
5	Fire safety directives letter No	DOE Cir. 1.3.2011		
6	Date of inspection	3.5.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Ashok Yadav (Estate Manager) & Sh. J R Meena (Principal)		
9	Year of construction	2014		
10	Applicant's letter No.	334 dated 6.4.2018	G+1	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>DOE CIR.1.3.2011</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Three	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr.	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Three	Provided	MR
	<b>e. Width of corridor</b>	1.50 Mtrs.	Provided	MR
	<b>f. Door size</b>	1 Mtr.	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
		12 a/c per hour		
	upper floors		Natural Ventilation	MR

5	<b>Fire Extinguishers</b>			
	total numbers	10 Nos. CO2, ABC	10 Nos.	M
	Types		CO2, ABC	MR
	ISI marking		ISI Marked	MR
6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b> ABC Fire Extinguisher provided near electric Panel.			

Fire protection systems provided in the building were checked/tested and found functional at the time of inspection. Keeping in view demmed compliance of the minimum standards on fire prevention & Fire Safety requirements as per DOE Cir. dated 1.3.2011, renewal of Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj  
ADO (Dwarka)

*Sey*  
31/5/18

490/DOCSW  
dt. 07/05/18

*DOCSW*

*dy*  
27/5/2018

1378/CR-12  
1115/11615 DCFO (S2)

*W*  
11/5



*CHOCSW*

m.scell FT 101  
11/5

FT is put up for signature please

*cfms24*  
m.scell 16/5

*Sey*  
15/5/18