

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/School/2018/NDZ/ 1063

Dated: 15/05/18

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sec. School**, at Pocket IV, Mayur Vihar, Phase-I, Delhi-91, owned/occupied by Govt. Girls Sec. School, comprised of ground plus one floors was issued Fire Safety Certificate vide letter no.F6/DFS/MS/School/2015/NDZ/358 Dated 13/03/15. The school building was inspected by the officer concerned of this department on 13/04/18 in the presence of **Mrs. Sadhna (H.O.S)** of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F16/Estate/CC/FS/2011/3298 to 3398 Dated 1.3.11 and found that the building is fit for occupancy class B 'Educational Building' for with effect from ...15/05/18 for a period of **three** years, subject to conditions, printed overleaf
Issued on.....15/05/18.....at New Delhi by

10/5
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

The Principal,
Govt. Girls Sec. School, Pocket IV,
Mayur Vihar, Phase-I, Delhi-91.

Copy to:-

1. The Dy. Director of Education
D-Block, Anand Vihar, Delhi.
2. The Principal,
Govt. Boys Sec. School, Pocket IV,
Mayur Vihar, Phase-I, Delhi-91.

1. Name & address of the building : S.K.V. at Pkt IV, Mayur Vihar Phase-1, Delhi-91.
2. Building is comprised of : G+1 upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2015/NDZ/358 dated
13/03/15
6. Fire Safety direction letter No : F16/Estate/CC/FS/2011/3298 to 3398 Dated 1.3.11
7. Date of Inspection : 13/04/18
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer
from the building side : Mrs. Sadhna (H.O.S)
10. Year of Construction : 1994
11. Applicant's letter No : DE.2(1)/SKV/1002036/Admn/Misc/2018/1311 Date-
12/03/18

No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 M N/A N/A	10 M 4.5 m N/A	MR MR N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	2 no N/A	Provided N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M N/A	1.45 M each N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.5 M	1.7 M	MR
	f. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	08 Nos. ABC & Co2 ISI marked	16 Nos. ABC & Co2 ISI marked	MR MR MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
7	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
3	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
17	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

N/12

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2015/NDZ/358 Dated 13/03/15 renewal under the Circular no. F16/Estate/CC/FS/2011/3298 to 3398 Dated 1.3.11 is recommended to renew Fire Safety Certificate.

R. K. Yadav
 Signature of the Inspecting Officer
 Name: R. K. Yadav
 Designation: ADO(LN)

submitter plan.
 DO(ED)
 DYCFD/NDZ
 CEQ. M.Scell
 FT/M.
 19/11/14

487/CFOSZ
 19/11/14

Sir, FT letter is put up for signature pl.
 Date
 2/8/2018
 CFO(NDZ) M.Scell 10/5