

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/SCHOOL/2018/SZ/ 1109

Dated: 16/5/18

**FIRE SAFETY CERTIFICATE**

Certified that the Happy English Public School located at RZ-G-13 Nanda Block, Mahavir Enclave, New Delhi-110045, School is running at ground and first floor of a building comprised of ground plus two upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/1180 dated 20.7.2016. The said School building was re-inspected by the officer concerned of Fire Service on 27.6.2016 in presence of Smt. S K Bajwa (Treasurer) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 and that the building is fit for occupancy class B "Educational building" with effect from 16/5/18 for a period of **three years**, subject to compliance of the conditions, printed overleaf.

Issued on 16/5/18 at New Delhi by

*U*  
16/5  
D/c (Vipin Kental)  
Chief Fire Officer  
*Seal*

Copy to:-

1. The Director, (Education), SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, N.Delhi.
2. Manager, Happy English Public School, RZ-G-13, Nanda Block, Mahavir Enclave, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



	Address of the building	Happy English Public School, RZ-G-13, Nanda Block, Mahavir Enclave, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	F6/DFS/MS/School/2016/SZ/1180 dated 20.7.2016		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	1.5.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. S K Bajwa (Treasurer)		
9	Year of construction	before 2010		
10	Applicant's letter No.	HEPS/Misc./2018 dated 17.3.2018	(Ground Plus two upper floors, School is running at ground & 1st floor.	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>D O E Circular dated 01.03.2011.</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	Two	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr. If less than 1.5 Mtr. additional staircase of .75 Mtr. Is required	0.87 & 1 Mtr.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	Provided	MR
	e. Width of corridor	N/A	1.45 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. each floor	4 Nos.	MR
	Types	Co2 OR ABC	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

4/8

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
0	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: provided near electric meter	ABC fire extinguisher MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.  
 Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required as per DOE Cir. Dated 1.3.2011 renewal of Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval and signature please.

*Sun*  
21/5/18

S.P. Bhardwaj  
ADO Dwarka

365/DOCSW  
07/05/2018

*DOCSW*

*DOCSW*

DOCSW (SL)

*DOCSW*

1275/CPSC  
14/5/16/15

FTB  
M/SCCL  
11/5

FT is put up for signature please.

CPSC M/SCCL 16/5

*Sun*  
15/5/18

