

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2018/SZ/ 1093

Dated: 16/5/18

FIRE SAFETY CERTIFICATE


Certified that the M/s KFC Restaurant (A unit of sapphire foods), UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058, is in the building comprised of basement, stilt, upper ground floor plus two upper floors but the restaurant is running at upper ground floor only, was issued FSC by this department vide letter F6/DFS/MS/EH/2014/SZ/1084 dated 28.08.2014 owned/occupied by M/s KFC Restaurant (A unit of sapphire foods) was re-inspected by the officers concerned of this department on 10.4.2018 in the presence of Sh. Amit Gulati (Restaurant Manager) and found that Management of M/s KFC Restaurant (A unit of sapphire foods) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Upper Ground Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....16/5/18..... at New Delhi.


(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The Manager,
M/s KFC Restaurant (A unit of sapphire foods),
UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058
2. The Dy. Health Officer,
S.D.M.C, Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, New Delhi-110027


D/C S.M.
16/5/18

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant (A unit of sapphire foods), UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058
2. Type of Occupancy : Group D (Assembly Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2014/SZ/1084 dated 28.08.2014
5. Fire Safety directives letter No : N/A
6. Date of inspection : 10.4.2018
7. Name of Inspecting Officers : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Amit Gulati (Restaurant Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 28.08.2014	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 4.5 mtrs N/A	12 mtrs 5.3 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s	02 no.'s (stilt to upper GF)	MR (restaurant at UGF only)
		N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms	190 & 90 cms	MR being old bldg.
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	One	N/A
	e. Width of Corridor			
		N/A	Opening in hall	N/A
	f. Door Size			
		02 mtrs	200 & 120 cms	MR
3.	Compartmentation			(Restaurant is at UGF only)
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			(Restaurant is at UGF only)
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 No.'s ABC/CO ₂	Provided	MR
			Provided	MR
		ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			(Restaurant is at UGF only)
	<ul style="list-style-type: none"> • Total numbers on ground floor • Length of hose reel hose • Hose diameter 	One 30 mtrs 5 mm	Provided	MR
			Provided	MR
			Provided	MR

7.	Automatic fire detection and alarming system	Smoke & Heat Required N/A Required Required	Provided UG Floor N/A Provided At exit	MR MR N/A MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System	(Restaurant is at UGF only)		
	• Basement	N/A	N/A	N/A
	• Ground Floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	(Restaurant is at UGF only)		
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants	01 No.	Provided	MR
	• Hose Box	01 No.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 mtrs	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	(Restaurant is at UGF only)		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

2/11

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings pointed out by this department vide letter no. F.6/DFS/MS/EH/2017/SZ/2272 dated 01.09.2017 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2014/SZ/1084 dated 28.08.2014 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten Signature]
17/4/18

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer

[Handwritten Signature]
17/4/18

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

207/2018
17/4/18

Dy. C.F.O. (South Zone)

[Handwritten Signature]
19/4



CFO SZ

M.Scell

FTM

U
2/5

F.T letter in put up for signature please.

1340/cb/8
7/5/16/11/5

CFO (SZ)

M.Scell

U
11/5

[Handwritten Signature]
09/5/18