

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2018/SZ/1106

Dated: 16/5/18

FIRE SAFETY CERTIFICATE

Certified that the S D M C Primary Model School Raj Nagar Extension-I & II, Palam Colony, New Delhi-110077, having two blocks namely old block & New Block , Old block comprised of ground plus one upper floor & New block ground plus two upper floors. The said building was re-inspected by the officer concerned of this department on 3.5.2018 in presence of Sh. Ramesh Kumar Gangele (HOS) IInd shift and found that that the school building , have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Saffety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi is fit for occupancy class B "Educational building" with effect from...16/5/18... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on ...16/5/18... at New Delhi by

u
16/5-
(Vipin Kental)
Chief Fire Officer
qc
Suy

Copy to:-

1. The Director, (Education), SDMC, 23rd floor Civic Centre, Minto Road, N.D.
2. The Principal, S D M C Primary Model School Raj Nagar Extension-I & II, Palam Colony, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	S D M C Primary Model School, Raj Nagar- Extension-II, Palam Colony, New Delhi-110077.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/680 dated 5.5.2015	
5	Fire safety directives letter No	DOE Cir. Dated 1.3.2011	
6	Date of inspection	3.5.2018	
7	Name of the inspecting Officers	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Ramesh Kumar Gangele (HOS) Shift II	
9	Year of construction	2003, 2011 New Block	
10	Applicant's letter No.	Nil dated 15.4.2018	Two blocks Viz: Old block Ground Plus One & New Block Ground Plus Two Upper Floors Two blocks (Both interconnected at 1st Floor.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	4.5 Mtr.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.23, 1.49 & 1.5 Mtrs.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	2 Nos.	MR
	e. Width of corridor	1.50 Mtr.	1.78 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers	Two Each floor per block.	10 Nos	MR
	Types	Co2 OR ABC	ABC	MR
	ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100 mm	N/A
	Number of Hydrants per floor	N/A	One	N/A
	hose Box	N/A	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	MR
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	Required	35 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: provided near electric panel		ABC fire extinguisher MR	

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed I compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. dated 1.3.2011, renewal of Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
3/5/18
S.P. Bhardwaj
ADO (Dwarka)

52.5/DOCSW
dt. 07/05/18

DOCSW

dhg
8/5/18

bcfo (2)

amp
8/5



1372/CF 52
196-7/16/15

Cfo-cy

m.scell FT/107
uc
11/5.

FT is put up for signature please